

Your Project Calculations



Project Name: MTSOLAR_4F87C82K76L2

S3D Model Link:

[https://platform.skyciv.com/structural?](https://platform.skyciv.com/structural?preload_name=MTSOLAR_4F87C82K76L2&preload_path=Shared%20Enterprise%20Folder/MT_Solar_Projects/9_2023)

[preload_name=MTSOLAR_4F87C82K76L2&preload_path=Shared%20Enterprise%20Folder/MT_Solar_Projects/9_2023](https://platform.skyciv.com/structural?preload_name=MTSOLAR_4F87C82K76L2&preload_path=Shared%20Enterprise%20Folder/MT_Solar_Projects/9_2023)

Public Model Link:

https://platform.skyciv.com/structural-viewer?project_id=oWDXF0xF2rFNbp0a2pXuD52AM7MhEMRJCjD1li81PuzB5300R3FZqsuQyEMKJNEP

Array Specification

Product:	Beam
Unique ID:	1P-0-6TOP-SD-45-L-4Hx2W-4G1E
Duty Classification:	SD
Module Width:	45.00 in
Module Length:	90.00in
Number of Rows:	4
Number of Columns:	2
Total Number of Modules:	8
Desired Tilt Angle:	35
Front Edge Clearance:	5
Total Array Height at Tilt:	13.65 ft
Total Frame Length:	15.00 ft
Frame Weight:	689 lbs
Array Dimensions N/S:	15.17 ft
Array Dimensions E/W:	15.17 ft
Rail Length:	182.00 in
Rail Spacing:	3.75 ft
Rail Check:	Not Checked

Support Specifications


Pole Size:	6in Pipe Sch 80
Pole Length above Grade:	9.35 ft
Number of Poles:	1
Pole Spacing:	0

Foundation Specifications

Foundation Type:	Square
Foundation Dimensions:	48 x 48 in
Foundation Depth (below grade):	Pile 1: 6.00 ft
Foundation Volume:	3.556 y ³
Foundation Result:	PASSED
Mount Twist:	0.000002 kip

Site Info

Risk Category:	I
Exposure:	C
Soil Classification:	sand
Site Location:	Midland, TX, USA
Wind Speed:	100 mph
Snow Load:	5 psf
Design Uplift Pressure:	Multiple pressures
Design Downforce Pressure:	Multiple pressures
Design Snow Pressure:	0.001924 ksf



Design Disclaimer


This software should be used for preliminary designs and should not be used as a final design unless reviewed, verified and designed by a qualified structural engineer.



AutoDesigner Input



```
{
  "wind_speed_override": null,
  "snow_load_override": null,
  "direct_snow_load": false,
  "product_type": "Beam",
  "project_id": "MTSOLAR_4F87C82K76L2",
  "site_address": "Midland, TX, USA",
  "module_width": 45,
  "module_length": 90,
  "number_rows": 4,
  "number_columns": 2,
  "pole_mount_section": "4_40",
  "core_pipe_width": 65,
  "core_pipe_section": "2_40",
  "adjuster_section": "2_40",
  "core_beam_height": 65,
  "core_beam_section": "HSS3x2x1/8",
  "main_pipe_section": "2_12GA",
  "pole_spacing": 15,
  "tilt_angle": 35,
  "ground_clearance": 5,
  "risk_category": "I",
  "exposure_category": "C",
  "frame_duty_override": "auto",
  "pole_override": "auto",
  "soil_type": "sand",
  "customer_foundation_override": "48_Square",
  "foundation_type": "Square",
  "foundation_size": 48,
  "check_rails": false
}
```

Design Notes:



- AISC Deflection checks are set to L/1 due to structure design intent
- Foundation Design and Sizing is approximate only










FEM Results (Envelope Worst Case for each member)







Reaction Forces for Foundation 1 (Node ID#1), (kip, kip-ft)

ASD Load Combination Results

Name	Fx	Fy	Fz	Mx	My	Mz
ULS: 1. D	0.0000	1.7293	0.0000	0.0000	-0.0000	0.0191
ULS: 2. D + L	0.0000	1.7293	0.0000	0.0000	-0.0000	0.0191
ULS: 3. D + (S or Lr or R)	0.0000	2.0879	0.0000	0.0000	-0.0000	0.0193
ULS: 3. D + (S or Lr or R)	0.0000	1.7293	0.0000	0.0000	-0.0000	0.0191
ULS: 4. D + 0.75L + 0.75(S or Lr or R)	0.0000	1.9982	0.0000	0.0000	-0.0000	0.0192
ULS: 4. D + 0.75L + 0.75(S or Lr or R)	0.0000	1.7293	0.0000	0.0000	-0.0000	0.0191
ULS: 5b. D + 0.7E	0.0000	1.7293	0.0000	0.0000	-0.0000	0.0191
ULS: 6b. D + 0.75L + 0.75(0.7)E + 0.75S	0.0000	1.9982	0.0000	0.0000	-0.0000	0.0192
ULS: 8. 0.6D + 0.7E	0.0000	1.0376	0.0000	0.0000	-0.0000	0.0114
ULS: 5a. D + 0.6W_Wind downforce Case A only	-2.3977	5.1535	-0.0000	0.0000	-0.0000	23.1579
ULS: 5a. D + 0.6W_Wind downforce Case B only	-2.3977	5.1535	-0.0000	0.0000	-0.0000	23.1579
ULS: 5a. D + 0.6W_Wind uplift Case A only	2.0231	-1.1600	-0.0000	0.0000	-0.0000	-18.5769
ULS: 5a. D + 0.6W_Wind uplift Case B only	1.6859	-0.6784	0.0000	0.0000	-0.0000	-22.2344
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case A only	-1.7983	4.5664	-0.0000	0.0000	-0.0000	17.3733
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case B only	-1.7983	4.5664	-0.0000	0.0000	-0.0000	17.3733
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case A only	1.5173	-0.1687	-0.0000	0.0000	-0.0000	-13.9277
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case B only	1.2644	0.1925	0.0000	0.0000	-0.0000	-16.6709
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case A only	-1.7983	4.2975	-0.0000	0.0000	-0.0000	17.3732
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case B only	-1.7983	4.2975	-0.0000	0.0000	-0.0000	17.3732
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case A only	1.5173	-0.4377	-0.0000	0.0000	-0.0000	-13.9279
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case B only	1.2644	-0.0765	0.0000	0.0000	-0.0000	-16.6710
ULS: 7. 0.6D + 0.6W_Wind downforce Case A only	-2.3977	4.4618	-0.0000	0.0000	-0.0000	23.1503
ULS: 7. 0.6D + 0.6W_Wind downforce Case B only	-2.3977	4.4618	-0.0000	0.0000	-0.0000	23.1503
ULS: 7. 0.6D + 0.6W_Wind uplift Case A only	2.0231	-1.8517	-0.0000	0.0000	-0.0000	-18.5845
ULS: 7. 0.6D + 0.6W_Wind uplift Case B only	1.6859	-1.3701	0.0000	0.0000	-0.0000	-22.2420

Worst Case Reactions LRFD

These calculations are taken directly from the FEA via SkyCiv and are used in the Concrete Checks of the Foundation Module.
Note: Worst case values are assumed as downforce wind load cases.

Result	Value (kip, kip-ft)
Axial	7.9615
Shear X	-3.9962
Shear Z	0.0000
Moment X	-0.0000
Moment Y (Twist)	0.0000
Moment Z	38.9442

Worst Case Reactions ASD

These results are taken from the worst case values in the above table and are used in the Soil Checks in the Foundation Module.
Note: Worst case values are assumed as downforce wind load cases.

Result	Value (kip, kip-ft)
Axial	5.1535
Shear X	-2.3977
Shear Z	0.0000
Moment X	0.0000
Moment Y (Twist)	0.0000
Moment Z	23.1579

Project Details

Design Code: AISC 360-16 LRFD
 Provision: LRFD
 Country: United States

User Name: sales@mtsolar.us
 Project Name: MTSOLAR_4F87C82K76L2
 Unit System: imperial



Design Input Information

Design Factors			
Φ_t	Φ_c	Φ_b	Φ_v
0.9	0.9	0.9	0.9

Design Materials			
ID	E (ksi)	F_y (ksi)	F_u (ksi)
1	29000	50	65

Section Dimensions								
ID	Name	d (in)	t_w (in)					
1	2in Pipe Sch 40	2.38	0.15					
4	4in Pipe Sch 40	4.50	0.24					
8	6in Pipe Sch 80	6.63	0.43					
ID	Name	d (in)	b (in)	t_w (in)	t_b (in)	r (in)		
15	HSS5x3x1/8	5.00	3.00	0.12	0.12	0.12		
ID	Name	d (in)	t_w (in)	b_t (in)	b_b (in)	t_t (in)	t_b (in)	r (in)
18	W6x9	5.90	0.17	3.94	3.94	0.21	0.21	0.25

Section Properties								
ID	Name	A (in ²)	J (in ⁴)	I_{yp} (in ⁴)	I_{zp} (in ⁴)	I_w (in ⁶)	S_{yp} (in ³)	S_{zp} (in ³)
1	2in Pipe Sch 40	1.07	1.33	0.67	0.67	0.00	0.76	0.76
4	4in Pipe Sch 40	3.17	14.47	7.23	7.23	0.00	4.31	4.31

8	6in Pipe Sch 80	8.40	80.98	40.49	40.49	0.00	16.60	16.60
15	HSS5x3x1/8	1.77	6.02	2.75	6.03	152.35	2.07	2.93
18	W6x9	2.68	0.04	2.20	16.40	17.70	1.72	6.23

Member Properties									
Member ID	Section ID	K _z L (ft)	K _y L (ft)	L _b (ft)	C _b	L S T	L S C	L D	
1	8	19.63	19.63	9.35	-	300	200	1	
2	4	1.30	1.30	2.00	-	300	200	1	
3	15	0.92	0.92	1.42	1.19,1.19,1.19,1.18,1.19,1.19,1.18,1.18,1.18,1.18,1.18,1.18,1.18,1.18,1.17,1.17,1.18,1.18,1.17,1.17,1.18,1.18,1.18,1.18	300	200	1	
4	15	2.44	2.44	3.75	1.68,1.68,1.68,1.68,1.68,1.68,1.67,1.67,1.66,1.62,1.67,1.67,1.66,1.63,1.67,1.67,1.65,1.69,1.67,1.67,1.65,1.72,1.67,1.67,1.66,1.65	300	200	1	
5	15	1.52	1.52	2.33	1.68,1.68,1.68,1.67,1.68,1.68,1.67,1.67,1.66,1.66,1.67,1.67,1.66,1.66,1.67,1.67,1.66,1.66,1.67,1.67,1.66,1.66,1.67	300	200	1	
6	15	0.92	0.92	1.42	1.19,1.19,1.19,1.18,1.19,1.19,1.18,1.18,1.18,1.18,1.18,1.18,1.18,1.18,1.17,1.17,1.18,1.18,1.17,1.17,1.18,1.18,1.18,1.18	300	200	1	
7	15	1.52	1.52	2.33	1.68,1.68,1.68,1.67,1.68,1.68,1.67,1.67,1.66,1.66,1.67,1.67,1.66,1.66,1.67,1.67,1.66,1.66,1.67,1.67,1.66,1.66,1.67	300	200	1	
8	18	7.88	7.88	3.75	2.33,2.33	300	200	1	
9	1	2.60	2.60	4.00	-	300	200	1	
10	15	2.44	2.44	3.75	1.68,1.68,1.68,1.68,1.68,1.68,1.67,1.67,1.66,1.62,1.67,1.67,1.66,1.63,1.67,1.67,1.65,1.69,1.67,1.67,1.65,1.72,1.67,1.67,1.66,1.65	300	200	1	
11	18	7.88	7.88	3.75	2.33,2.33	300	200	1	
12	4	1.30	1.30	2.00	-	300	200	1	
13	18	4.88	4.00	7.50	1.05,1.05,1.05,1.05,1.05,1.05,1.05,1.05,1.06,1.05,1.05,1.05,1.06,1.05,1.05,1.05,1.08,1.05,1.05,1.05,1.07,1.05,1.05,1.05,1.05	300	200	1	
14	18	4.88	4.00	7.50	1.05,1.05,1.05,1.05,1.05,1.05,1.05,1.05,1.03,1.05,1.05,1.05,1.03,1.05,1.05,1.05,1.21,1.05,1.05,1.05,1.68,1.05,1.05,1.05,1.03	300	200	1	
15	18	7.88	7.88	3.75	2.33,2.33	300	200	1	
16	18	7.88	7.88	3.75	2.33,2.33	300	200	1	

Member Design Capacity

Member ID	$\Phi_t P_n$ (kip)	$\Phi_c P_n$ (kip)	$\Phi_b M_{zn}$ (k-ft)	$\Phi_b M_{yn}$ (k-ft)	$\Phi_v V_{yn}$ (kip)	$\Phi_v V_{zn}$ (kip)
1	378.22	162.87	62.23	62.23	113.47	113.47
2	142.83	141.72	16.17	16.17	42.85	42.85
3	79.65	74.02	10.99	4.60	29.14	16.61
4	79.65	72.01	10.99	4.60	29.14	16.61
5	79.65	73.44	10.99	4.60	29.14	16.61
6	79.65	74.02	10.99	4.60	29.14	16.61
7	79.65	73.44	10.99	4.60	29.14	16.61
8	120.60	54.44	23.36	6.45	30.09	45.74
9	48.35	43.11	2.85	2.85	14.51	14.51

10	79.65	72.01	10.99	4.60	29.14	16.61
11	120.60	54.44	23.36	6.45	30.09	45.74
12	142.83	141.72	16.17	16.17	42.85	42.85
13	120.60	98.23	18.49	6.45	30.09	45.74
14	120.60	98.23	18.13	6.45	30.09	45.74
15	120.60	54.44	23.36	6.45	30.09	45.74
16	120.60	54.44	23.36	6.45	30.09	45.74

Design Ratio


Member ID	P	M _z	M _y	V _y	V _z	(P,M _z ,M _y)	Worst LC	KL/r	δ	Status
1	0.049	0.626	0.000	0.035	0.000	0.650	#13	0.537	Not Required	Pass
2	0.001	0.418	0.242	0.089	0.047	0.661	#13	0.034	Not Required	Pass
3	0.004	0.734	0.045	0.074	0.005	0.773	#13	0.044	Not Required	Pass
4	0.004	0.713	0.093	0.072	0.012	0.769	#13	0.078	Not Required	Pass
5	0.004	0.455	0.096	0.074	0.014	0.474	#13	0.073	Not Required	Pass
6	0.004	0.734	0.045	0.074	0.005	0.773	#13	0.044	Not Required	Pass
7	0.004	0.455	0.096	0.074	0.014	0.474	#13	0.073	Not Required	Pass
8	0.000	0.083	0.045	0.034	0.003	0.120	#13	Not Required	Not Required	Pass
9	0.003	0.068	0.050	0.001	0.000	0.119	#13	0.198	Not Required	Pass
10	0.004	0.713	0.093	0.072	0.012	0.769	#13	0.078	Not Required	Pass
11	0.000	0.085	0.045	0.035	0.003	0.122	#13	Not Required	Not Required	Pass
12	0.001	0.418	0.242	0.089	0.047	0.661	#13	0.034	Not Required	Pass
13	0.002	0.243	0.096	0.052	0.005	0.311	#13	0.177	Not Required	Pass
14	0.002	0.242	0.096	0.051	0.005	0.305	#13	0.177	Not Required	Pass
15	0.000	0.085	0.045	0.035	0.003	0.122	#13	Not Required	Not Required	Pass
16	0.000	0.083	0.045	0.034	0.003	0.120	#13	Not Required	Not Required	Pass

Definitions

Φ_t	Safety factor for tensile
Φ_c	Safety factor for compression
Φ_b	Safety factor for flexure
Φ_v	Safety factor for shear
E	Modulus of elasticity
F _y	Specified minimum yield stress
F _u	Specified minimum tensile strength
A	Cross-sectional area
J	Torsional constant
I _{yp}	Moment of inertia about the Y axes
I _{zp}	Moment of inertia about the Z axes
I _w	Warping constant
S _{yp}	Plastic section modulus about the Y axis
S _{zp}	Plastic section modulus about the Z axis
KL	Effective length
C _b	Buckling modification factor (from all load combinations)
L _b	Length between braced points
LST	Limited slenderness for tension
LSC	Limited slenderness for compression
LD	Limited deflection
P _n	Nominal axial strength (tension/compression)
M _n	Nominal flexural strength (about Z/Y axis)
V _n	Nominal shear strength (along Z/Y axis)
P	Design ratio in case of axial force
M _z	Design ratio in case of bending about Z axis
M _y	Design ratio in case of bending about Y axis
V _y	Design ratio in case of shear along Y axis
V _z	Design ratio in case of shear along Z axis
(P,M _z ,M _y)	Design ratio in case of axial force and bending action
KL/r	Design ratio in case of section slenderness
δ	Design ratio in case of member deflection
OK	Capacity is provided

ON
NG

Capacity is provided
Capacity is not provided

REFERENCES	CALCULATIONS	RESULTS																										
	SkyCiv Foundation Design Pile Foundation Design Information : Design code : IBC 2021 (International Building Code) Unit System : Imperial																											
	Pile Input  Geometry Pile shape: rectangular b = 48 in - Pile width D = 48 in - Pile depth L = 6 ft - Total pile length h1 = 0 ft - Lateral load height from the top of the pile, h2 = 0 ft - Depth to resisting surface he = 0 ft - Length of pile above the ground Tabulation of Soil Parameters <table><thead><tr><th>Layer</th><th>Label</th><th>Allowable Bearing Pressure (qa) (psf)</th><th>Allowable Lateral Pressure (R) (psf/ft)</th></tr></thead><tbody><tr><td>1</td><td>Sand, silty sand, clayey sand, silty gravel & clayey gravel</td><td>2000.000</td><td>150.000</td></tr></tbody></table> Tabulation of Loads <table><thead><tr><th>Load Component</th><th>ASD</th><th>LRFD</th></tr></thead><tbody><tr><td>P (kip)</td><td>5.154</td><td>7.962</td></tr><tr><td>Vx (kip)</td><td>-2.398</td><td>-3.996</td></tr><tr><td>Vz (kip)</td><td>0.000</td><td>0.000</td></tr><tr><td>Mx (kipft)</td><td>0.000</td><td>0.000</td></tr><tr><td>Mz (kipft)</td><td>23.158</td><td>38.944</td></tr></tbody></table> Material Properties f'ck = 2.5 ksi - Concrete strength,	Layer	Label	Allowable Bearing Pressure (qa) (psf)	Allowable Lateral Pressure (R) (psf/ft)	1	Sand, silty sand, clayey sand, silty gravel & clayey gravel	2000.000	150.000	Load Component	ASD	LRFD	P (kip)	5.154	7.962	Vx (kip)	-2.398	-3.996	Vz (kip)	0.000	0.000	Mx (kipft)	0.000	0.000	Mz (kipft)	23.158	38.944	
Layer	Label	Allowable Bearing Pressure (qa) (psf)	Allowable Lateral Pressure (R) (psf/ft)																									
1	Sand, silty sand, clayey sand, silty gravel & clayey gravel	2000.000	150.000																									
Load Component	ASD	LRFD																										
P (kip)	5.154	7.962																										
Vx (kip)	-2.398	-3.996																										
Vz (kip)	0.000	0.000																										
Mx (kipft)	0.000	0.000																										
Mz (kipft)	23.158	38.944																										
	Required depth to resist lateral loads (ASD) H - Point of application of the lateral load H = h1 + h2 + he H = (0 ft) + (0 ft) + (0 ft) H = 0 ft Considering x-direction: Ho - Lateral force per length of pile, Ho = Vx / (1.57 D) Ho = (-2.398 kip) / (1.57 x (48 in)) Ho = -0.38185 kip/ft Mo - Moment per length of pile, Mo = (Mz + (Vx H)) / (1.57 D)																											

	$M_o = \frac{(23.158 \text{ kipft}) + ((-2.398 \text{ kip}) \times (0 \text{ ft}))}{1.57 \times (48 \text{ in})}$ $M_o = 3.6876 \text{ kipft/ft}$ Required depth of embedment in earth: $L_x^3 - \left(14.14 \times \frac{H_o \times L_x}{R}\right) - \left(18.85 \times \frac{M_o}{R}\right) = 0$ Solving the cubic equation: $L_{e,x} = 5.523 \text{ ft}$ - Required depth in x-direction, Considering z-direction: $L_{e,z} = 0 \text{ ft}$ - Required depth in z-direction, Minimum embedded depth required: $L_{e,req}$ - Depth of pile required, $L_{e,req} = MAX[L_{e,x}, L_{e,z}]$ $L_{e,req} = MAX[(5.523 \text{ ft}), (0 \text{ ft})]$ $L_{e,req} = 5.523 \text{ ft}$ L_e - Actual embedded length of pile, $L_e = L - h_e - h_2$ $L_e = (6 \text{ ft}) - (0 \text{ ft}) - (0 \text{ ft})$ $L_e = 6 \text{ ft}$ <i>Ratio</i> - Embedded depth $Ratio = \frac{L_{e,req}}{L_e}$ $Ratio = \frac{(5.523 \text{ ft})}{(6 \text{ ft})}$ $Ratio = 0.9205$	Status: PASS Ratio: 0.920
	End-bearing Capacity (ASD) A - Pile cross-section area $A = b \ D$ $A = (48 \text{ in}) \times (48 \text{ in})$ $A = 16 \text{ ft}^2$ q - End-bearing pressure $q = \frac{P_v}{A}$ $q = \frac{(5.154 \text{ kip})}{(16 \text{ ft}^2)}$ $q = 0.32213 \text{ kip/ft}^2$ Check bearing capacity ratio: <i>Ratio</i> - Capacity $Ratio = \frac{q}{q_o}$ $Ratio = \frac{(0.32213 \text{ kip/ft}^2)}{(2000 \text{ psf})}$ $Ratio = 0.16106$	Status: PASS Ratio: 0.160
Czerniak	Lateral Soil Pressure (ASD): L/D - Length to least lateral dimension ratio, $L/D = \frac{L}{D}$ $L/D = \frac{(6 \text{ ft})}{(48 \text{ in})}$	

$$L/D = 1.5$$

Since $L/D \leq 10$,

Pile is short.

Considering x-direction:

$H_o = -0.38185$ kip/ft - Lateral force per length of pile,

$M_o = 3.6876$ kipft/ft - Overturning moment per length of pile,

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (3.6876 \text{ kipft/ft}) \times (6 \text{ ft})) + (3 \times (-0.38185 \text{ kip/ft}) \times (6 \text{ ft})^2)}{(6 \times (3.6876 \text{ kipft/ft})) + (4 \times (-0.38185 \text{ kip/ft}) \times (6 \text{ ft}))}$$

$$a = 4.1464 \text{ ft}$$

p - Earth pressure against the pile at distance $a/2$ from resting surface,

$$p = \frac{0.75 [(4 M_o) + (3 H_o L_e)]^2}{L_e^3 [(3 M_o) + (2 H_o L_e)]}$$

$$p = \frac{0.75 \times [(4 \times (3.6876 \text{ kipft/ft})) + (3 \times (-0.38185 \text{ kip/ft}) \times (6 \text{ ft}))]^2}{(6 \text{ ft})^3 \times [(3 \times (3.6876 \text{ kipft/ft})) + (2 \times (-0.38185 \text{ kip/ft}) \times (6 \text{ ft}))]}$$

$$p = 0.19947 \text{ kip/ft}^2$$

s - Earth pressure against the pile at distance L_e ,

$$s = \frac{6 [(2 M_o) + (H_o L_e)]}{L_e^2}$$

$$s = \frac{6 \times [(2 \times (3.6876 \text{ kipft/ft})) + ((-0.38185 \text{ kip/ft}) \times (6 \text{ ft}))]}{(6 \text{ ft})^2}$$

$$s = 0.84735 \text{ kip/ft}^2$$

Check lateral soil pressure capacity:

p_a - Allowable lateral soil pressure at depth $a/2$,

$$p_a = R \frac{a}{2}$$

$$p_a = (150 \text{ psf/ft}) \times \frac{(4.1464 \text{ ft})}{2}$$

$$p_a = 0.31098 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity

$$\text{Ratio} = \frac{p}{p_a}$$

$$\text{Ratio} = \frac{(0.19947 \text{ kip/ft}^2)}{(0.31098 \text{ kip/ft}^2)}$$

$$\text{Ratio} = 0.64141$$

p_s - Allowable lateral soil pressure at depth L_e ,

$$p_s = R L_e$$

$$p_s = (150 \text{ psf/ft}) \times (6 \text{ ft})$$

$$p_s = 0.9 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity


$$\text{Ratio} = \frac{s}{p_s}$$


$$\text{Ratio} = \frac{(0.84735 \text{ kip/ft}^2)}{(0.9 \text{ kip/ft}^2)}$$

$$\text{Ratio} = 0.9415$$

Status: **PASS**
Ratio: **0.640**

Status: **PASS**
Ratio: **0.940**





Shear force and Bending moment (x-direction, LRFD)

H_o - Lateral force per length of pile,

$$H_o = \frac{V_x}{1.57 D}$$

$$H_o = \frac{(-3.996 \text{ kip})}{1.57 \times (48 \text{ in})}$$

$$H_o = -0.63631 \text{ kip/ft}$$

M_o - Moment per length of pile,

$$M_o = \frac{M_x + (V_x H)}{1.57 D}$$

$$M_o = \frac{(38.944 \text{ kipft}) + ((-3.996 \text{ kip}) \times (0 \text{ ft}))}{1.57 \times (48 \text{ in})}$$

$$M_o = 6.2013 \text{ kipft/ft}$$

E - Distance from lateral load to resisting surface,

$$E = \frac{M_o}{H_o}$$

$$E = \frac{(6.2013 \text{ kipft/ft})}{(-0.63631 \text{ kip/ft})}$$

$$E = 9.7457 \text{ ft}$$

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (6.2013 \text{ kipft/ft}) \times (6 \text{ ft})) + (3 \times (-0.63631 \text{ kip/ft}) \times (6 \text{ ft})^2)}{(6 \times (6.2013 \text{ kipft/ft})) + (4 \times (-0.63631 \text{ kip/ft}) \times (6 \text{ ft}))}$$

$$a = 4.1455 \text{ ft}$$

V_{max} - Max shear force located at depth a ,

$$V_{max} = (H_o D) \left[1 - \left[3 \left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{L_e} \right)^2 \right] + \left[4 \left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{L_e} \right)^3 \right] \right]$$

$$V_{max} = ((-0.63631 \text{ kip/ft}) \times (48 \text{ in})) \times \left[1 - \left[3 \times \left(\frac{4 \times (9.7457 \text{ ft})}{(6 \text{ ft})} + 3 \right) \times \left(\frac{(4.1455 \text{ ft})}{(6 \text{ ft})} \right)^2 \right] + \left[4 \times \left(\frac{3 \times (9.7457 \text{ ft})}{(6 \text{ ft})} + 2 \right) \times \left(\frac{(4.1455 \text{ ft})}{(6 \text{ ft})} \right)^3 \right] \right]$$

$$V_{max} = 8.994 \text{ kip}$$

M_{max} - Max bending moment located at depth $a/2$,

$$M_{max} = (H_o D L_e) \left[\left(\frac{E}{L_e} + \frac{a}{2 L_e} \right) - \left[\left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{2 L_e} \right)^3 \right] + \left[\left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{2 L_e} \right)^4 \right] \right]$$

$$M_{max} = ((-0.63631 \text{ kip/ft}) \times (48 \text{ in}) \times (6 \text{ ft})) \times \left[\left(\frac{(9.7457 \text{ ft})}{(6 \text{ ft})} + \frac{(4.1455 \text{ ft})}{2 \times (6 \text{ ft})} \right) - \left[\left(\frac{4 \times (9.7457 \text{ ft})}{(6 \text{ ft})} + 3 \right) \times \left(\frac{(4.1455 \text{ ft})}{2 \times (6 \text{ ft})} \right)^3 \right] + \left[\left(\frac{3 \times (9.7457 \text{ ft})}{(6 \text{ ft})} + 2 \right) \times \left(\frac{(4.1455 \text{ ft})}{2 \times (6 \text{ ft})} \right)^4 \right] \right]$$

		$M_{max} = 25.596 \text{ kipft}$	
		Minimum Reinforcement Check (LRFD) Parameters: $f'_{ck} = 2.5 \text{ ksi}$ - Concrete strength, $f_{yk} = 60 \text{ ksi}$ - Longitudinal reinforcement strength, $\phi = 0.65$ - Reduction factor for axial strength, $\alpha = 0.8$ - Alpha factor for axial strength, $A_g = 2304 \text{ in}^2$ - Gross area of concrete, Longitudinal reinforcement: Required reinforcement due to axial load, $A_{st,required}$ $A_{st,required}$ $A_{st,required} = \text{Min} \left[\frac{\frac{P}{\phi \alpha} - (0.85 f'_{ck} A_g)}{f_{yk} - (0.85 f'_{ck})}, (0.08 A_g) \right]$ $A_{st,required} = \text{Min} \left[\frac{\frac{(7.962 \text{ kip})}{(0.65) \times (0.8)} - (0.85 \times (2.5 \text{ ksi}) \times (2304 \text{ in}^2))}{(60 \text{ ksi}) - (0.85 \times (2.5 \text{ ksi}))}, (0.08 \times (2304 \text{ in}^2)) \right]$ $A_{st,required} = -84.332 \text{ in}^2$ A_{min} - Governing minimum reinforcement area, $A_{min} = \text{Max} [A_{st,required}, (0.0018 A_g)]$ $A_{min} = \text{Max} [(-84.332 \text{ in}^2), (0.0018 \times (2304 \text{ in}^2))]$ $A_{min} = 4.1472 \text{ in}^2$ n_{rebar} - Required number of reinforcement, $n_{rebar} = \frac{A_{min}}{A_{rebar}}$ $n_{rebar} = \frac{(4.1472 \text{ in}^2)}{(0.3068 \text{ in}^2)}$ $n_{rebar} = 14$ A_{st} - Actual total reinforcement area, $A_{st} = n_{rebar} \frac{\pi d_{bar}^2}{4}$ $A_{st} = (14) \times \frac{\pi \times (0.625 \text{ in})^2}{4}$ $A_{st} = 4.2951 \text{ in}^2$ Ratio - Capacity $\text{Ratio} = \frac{A_{min}}{A_{st}}$ $\text{Ratio} = \frac{(4.1472 \text{ in}^2)}{(4.2951 \text{ in}^2)}$ $\text{Ratio} = 0.96556$ 25.2.3 s_{rebar} - Minimum spacing of reinforcement, $s_{rebar} = \text{Max} [1.5, (1.5 d_{bar})]$ $s_{rebar} = \text{Max} [1.5, (1.5 \times (0.625 \text{ in}))]$ $s_{rebar} = 1.5 \text{ in}$ Ties: 25.7.2.2 Since longitudinal reinforcement is $\leq \text{No. } 10\phi$: Use #3(0.375 in) 25.7.2.1 s_{ties} - Maximum spacing of ties, $s_{ties} = \text{Min} [(16 d_{bar}), (48 d_{ties}), \text{Min}(D, b)]$ $s_{ties} = \text{Min} [(16 \times (0.625 \text{ in})), (48 \times (0.375 \text{ in})), \text{Min}((48 \text{ in}), (48 \text{ in}))]$ $s_{ties} = 10 \text{ in}$ Summary: Main reinforcement: 14 - #5 (0.625 in)	Status: PASS Ratio: 0.970

	Ties: #3(0.375 in) - 10 in	
22.4.2.2	Axial Compression Strength (ACI 318-19, LRFD) ϕP_N - Allowable axial compressive strength $\phi P_N = \phi 0.80 [(0.85 f'_{ck} [A_g - A_{st}]) + (f_{yk} A_{st})]$ $\phi P_N = (0.65) \times 0.80 \times [(0.85 \times (2.5 \text{ ksi}) \times [(2304 \text{ in}^2) - (4.2951 \text{ in}^2)]) + ((60 \text{ ksi}) \times (4.2951 \text{ in}^2))]$ $\phi P_N = 2675.2 \text{ kip}$ Ratio - Capacity $\text{Ratio} = \frac{P}{\phi P_N}$ $\text{Ratio} = \frac{(7.962 \text{ kip})}{(2675.2 \text{ kip})}$ $\text{Ratio} = 0.0029762$	Status: PASS Ratio: 0.000
22.5.2.2	Shear Strength (ACI 318-19, LRFD) Parameters: $b_w = 48 \text{ in}$ - Effective width, d - Effective depth $d = 0.80 D$ $d = 0.80 \times (48 \text{ in})$ $d = 38.4 \text{ in}$	
22.5.5.1.3	λ_s - size effect modification factor $\lambda_s = \text{MIN} \left[\sqrt{\frac{2}{1 + \frac{d}{10}}}, 1 \right]$ $\lambda_s = \text{MIN} \left[\sqrt{\frac{2}{1 + \frac{(38.4 \text{ in})}{10}}}, 1 \right]$ $\lambda_s = 0.64282$	
22.5.5.1.1	The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$, $V_{c,max}$ - Max shear strength of concrete $V_{c,max} = 5 \lambda_s \sqrt{f'_{ck}} b_w d$ $V_{c,max} = 5 \times (0.64282) \times \sqrt{(2500 \text{ psi})} \times (48 \text{ in}) \times (38.4 \text{ in})$ $V_{c,max} = 296.21 \text{ kip}$	
22.5.5.1.1(a)	The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$, $P = 7.962 \text{ kip} \rightarrow 7962 \text{ lbf}$, $V_{c,a}$ - Shear strength of concrete (a) $V_{c,a} = \left[2 \lambda_s \sqrt{f'_{ck}} + \frac{P}{6 A_g} \right] b_w d$ $V_{c,a} = \left[2 \times (0.64282) \times \sqrt{(2500 \text{ psi})} + \frac{(7962 \text{ lbf})}{6 \times (2304 \text{ in}^2)} \right] \times (48 \text{ in}) \times (38.4 \text{ in})$ $V_{c,a} = 119.55 \text{ kip}$	
22.5.5.1.2	The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$, $V_{c,b}$ - Shear strength of concrete (b) $V_{c,b} = \left[2 \lambda_s \sqrt{f'_{ck}} + (0.05 f'_{ck}) \right] b_w d$ $V_{c,b} = \left[2 \times (0.64282) \times \sqrt{(2500 \text{ psi})} + (0.05 \times (2500 \text{ psi})) \right] \times (48 \text{ in}) \times (38.4 \text{ in})$ $V_{c,b} = 348.89 \text{ kip}$ V_c - Governing shear strength of concrete $V_c = \text{Min} [V_{c,max}, V_{c,a}, V_{c,b}]$ $V_c = \text{Min} [(296.21 \text{ kip}), (119.55 \text{ kip}), (348.89 \text{ kip})]$ $V_c = 119.55 \text{ kip}$	

22.5.1.2	The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$, $V_{s,a}$ - Shear strength of steel (a) $V_{s,a} = 8 \sqrt{f'_{ck}} b_w d$ $V_{s,a} = 8 \times \sqrt{(2500 \text{ psi})} \times (48 \text{ in}) \times (38.4 \text{ in})$ $V_{s,a} = 737.28 \text{ kip}$ A_v - Ties rebar area, $A_v = \frac{\pi d_{ties}^2}{4}$ $A_v = \frac{\pi \times (0.375 \text{ in})^2}{4}$ $A_v = 0.11045 \text{ in}^2$ 22.5.8.5.3 $V_{s,b}$ - Shear strength of steel (b) $V_{s,b} = \frac{2 A_v f_{ywk} d}{s_{ties}}$ $V_{s,b} = \frac{2 \times (0.11045 \text{ in}^2) \times (60 \text{ ksi}) \times (38.4 \text{ in})}{(10 \text{ in})}$ $V_{s,b} = 50.894 \text{ kip}$ V_s - Governing shear strength of steel $V_s = MIN[V_{s,a}, V_{s,b}]$ $V_s = MIN[(737.28 \text{ kip}), (50.894 \text{ kip})]$ $V_s = 50.894 \text{ kip}$ 22.5.1.1 ϕV_n - Allowable shear strength $\phi V_n = \phi (V_c + V_s)$ $\phi V_n = (0.65) \times ((119.55 \text{ kip}) + (50.894 \text{ kip}))$ $\phi V_n = 110.79 \text{ kip}$ Considering x-direction: $V_{max} = 8.994 \text{ kip}$ - Maximum shear force in the x-direction, $Ratio$ - Capacity $Ratio = \frac{V_{max}}{\phi V_n}$ $Ratio = \frac{(8.994 \text{ kip})}{(110.79 \text{ kip})}$ $Ratio = 0.081182$	Status: PASS Ratio: 0.080
14.5.2.1b	Flexural Strength (ACI 318-19, LRFD) S_m - Section modulus $S_m = \frac{b D^2}{6}$ $S_m = \frac{(48 \text{ in}) \times (48 \text{ in})^2}{6}$ $S_m = 18432 \text{ in}^3$ $\lambda = 1$ - Concrete modification factor (Normal concrete), Allowable flexural strength: M_n shall be the lesser of: $\phi M_{n,1}$ $\phi M_{n,1} = \phi \times 5 \times \lambda \times \sqrt{f'_c} \times S_m$ $\phi M_{n,1} = 0.65 \times 5 \times 1 \times \sqrt{(2.5 \text{ ksi})} \times 18432.001 \text{ in}^3$ $\phi M_{n,1} = 249.600 \text{ kip ft}$ $\phi M_{n,2}$ $\phi M_{n,2} = 0.85 f'_t S_m$	

	$\phi M_{n,2} = (0.65) \times 0.85 \times (2.5 \text{ ksi}) \times (18432 \text{ in}^3)$ $\phi M_{n,2} = 2121.6 \text{ kipft}$ Therefore, ϕM_n - Allowable flexural strength, $\phi M_n = \text{MIN}[\phi M_{n,1}, \phi M_{n,2}]$ $\phi M_n = \text{MIN}[(249.6 \text{ kipft}), (2121.6 \text{ kipft})]$ $\phi M_n = 249.6 \text{ kipft}$ Considering x-direction: $M_{max} = 25.596 \text{ kipft}$ - Maximum moment in the x-direction, <i>Ratio</i> - Capacity $\text{Ratio} = \frac{M_{max}}{\phi M_n}$ $\text{Ratio} = \frac{(25.596 \text{ kipft})}{(249.6 \text{ kipft})}$ $\text{Ratio} = 0.10255$	
		Status: PASS Ratio: 0.100