

Your Project Calculations



Project Name: Wilkes_rev1

S3D Model Link:

https://platform.skyciv.com/structural?preload_name=Wilkes_rev1&preload_path=Shared%20Enterprise%20Folder/MT_Solar_Projects/9_2023

Public Model Link:

https://platform.skyciv.com/structural-viewer?project_id=xjpv703UrgnG8lfH4nJAmmhIU8rcwVvtuVyzDUrtDFgKbg21KkHkcXwAkQilkyB7

Array Specification

Product:	Beam
Unique ID:	2P-15-6TOP-SD-45-L-3Hx5W-BEHA
Duty Classification:	SD
Module Width:	41.10 in
Module Length:	74.00in
Number of Rows:	3
Number of Columns:	5
Total Number of Modules:	15
Desired Tilt Angle:	45
Front Edge Clearance:	5
Total Array Height at Tilt:	12.31 ft
Total Frame Length:	30.00 ft
Frame Weight:	1340 lbs
Array Dimensions N/S:	10.40 ft
Array Dimensions E/W:	31.25 ft
Rail Length:	124.80 in
Rail Spacing:	3.08 ft
Rail Check:	Not Checked

Support Specifications


Pole Size:	6in Pipe Sch 80
Pole Length above Grade:	8.68 ft
Number of Poles:	2
Pole Spacing:	15 ft

Foundation Specifications

Foundation Type:	Round
Foundation Dimensions:	Ø36 in
Foundation Depth (below grade):	Pile 1: 8.25 ft Pile 2: 8.25 ft
Foundation Volume:	4.320 y ³
Foundation Result:	PASSED
Mount Twist:	0.786881 kip

Site Info

Risk Category:	I
Exposure:	C
Soil Classification:	sand
Site Location:	Daniel, WY, USA
Wind Speed:	115 mph
Snow Load:	85 psf
Design Uplift Pressure:	Multiple pressures
Design Downforce Pressure:	Multiple pressures
Design Snow Pressure:	0.023367 ksf



Design Disclaimer


This software should be used for preliminary designs and should not be used as a final design unless reviewed, verified and designed by a qualified structural engineer.


AutoDesigner Input

```
{
  "product_type": "Beam",
  "project_id": "Wilkes_rev1",
  "site_address": "Daniel, WY, USA",
  "module_width": 41.1,
  "module_length": 74,
  "number_rows": 3,
  "number_columns": 5,
  "pole_mount_section": "4_40",
  "core_pipe_width": 65,
  "core_pipe_section": "2_40",
  "adjuster_section": "2_40",
  "core_beam_height": 65,
  "core_beam_section": "HSS3x2x1/8",
  "main_pipe_section": "2_12GA",
  "pole_spacing": 15,
  "tilt_angle": 45,
  "ground_clearance": 5,
  "risk_category": "I",
  "exposure_category": "C",
  "frame_duty_override": "auto",
  "pole_override": "auto",
  "soil_type": "sand",
  "customer_foundation_override": "36_Round",
  "foundation_type": "Round",
  "foundation_size": 36,
  "check_rails": false,
  "wind_speed_override": 115,
  "snow_load_override": 85,
  "direct_snow_load": false
}
```


Design Notes:

- AISC Deflection checks are set to L/1 due to structure design intent
- Foundation Design and Sizing is approximate only







 SkyCiv



 SkyCiv







SkyCiv




SkyCiv

FEM Results (Envelope Worst Case for each member)







Reaction Forces for Foundation 1 (Node ID#1), (kip, kip-ft)

ASD Load Combination Results

Name	Fx	Fy	Fz	Mx	My	Mz
ULS: 1. D	0.0000	1.4699	-0.0294	-0.0682	0.0625	0.0160
ULS: 2. D + L	0.0000	1.4699	-0.0294	-0.0682	0.0625	0.0160
ULS: 3. D + (S or Lr or R)	0.0000	4.0475	-0.0996	-0.2312	0.2115	0.0283
ULS: 3. D + (S or Lr or R)	0.0000	1.4699	-0.0294	-0.0682	0.0625	0.0160
ULS: 4. D + 0.75L + 0.75(S or Lr or R)	0.0000	3.4031	-0.0820	-0.1904	0.1742	0.0252
ULS: 4. D + 0.75L + 0.75(S or Lr or R)	0.0000	1.4699	-0.0294	-0.0682	0.0625	0.0160
ULS: 5b. D + 0.7E	0.0000	1.4699	-0.0294	-0.0682	0.0625	0.0160
ULS: 6b. D + 0.75L + 0.75(0.7)E + 0.75S	0.0000	3.4031	-0.0820	-0.1904	0.1742	0.0252
ULS: 8. 0.6D + 0.7E	0.0000	0.8820	-0.0176	-0.0409	0.0375	0.0096
ULS: 5a. D + 0.6W_Wind downforce Case A only	-2.5934	4.0633	-0.1494	-0.3356	0.4453	23.7188
ULS: 5a. D + 0.6W_Wind downforce Case B only	-2.5934	4.0633	-0.1494	-0.3356	0.4453	23.7188
ULS: 5a. D + 0.6W_Wind uplift Case A only	1.8761	-0.4062	0.0571	0.1242	-0.2142	-15.5307
ULS: 5a. D + 0.6W_Wind uplift Case B only	1.6554	-0.1854	0.0475	0.1027	-0.1832	-18.8498
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case A only	-1.9450	5.3482	-0.1720	-0.3910	0.4614	17.8023
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case B only	-1.9450	5.3482	-0.1720	-0.3910	0.4614	17.8023
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case A only	1.4071	1.9961	-0.0171	-0.0461	-0.0333	-11.6348
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case B only	1.2415	2.1616	-0.0244	-0.0622	-0.0101	-14.1241
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case A only	-1.9450	3.4150	-0.1194	-0.2688	0.3496	17.7931
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case B only	-1.9450	3.4150	-0.1194	-0.2688	0.3496	17.7931
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case A only	1.4071	0.0629	0.0355	0.0761	-0.1450	-11.6440
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case B only	1.2415	0.2284	0.0282	0.0600	-0.1218	-14.1333
ULS: 7. 0.6D + 0.6W_Wind downforce Case A only	-2.5934	3.4753	-0.1376	-0.3083	0.4203	23.7124
ULS: 7. 0.6D + 0.6W_Wind downforce Case B only	-2.5934	3.4753	-0.1376	-0.3083	0.4203	23.7124
ULS: 7. 0.6D + 0.6W_Wind uplift Case A only	1.8761	-0.9941	0.0689	0.1515	-0.2392	-15.5371
ULS: 7. 0.6D + 0.6W_Wind uplift Case B only	1.6554	-0.7734	0.0592	0.1300	-0.2082	-18.8562

Worst Case Reactions LRFD

These calculations are taken directly from the FEA via SkyCiv and are used in the Concrete Checks of the Foundation Module.
Note: Worst case values are assumed as downforce wind load cases.

Result	Value (kip, kip-ft)
Axial	8.0492
Shear X	-4.3223
Shear Z	-0.2705
Moment X	-0.6097
Moment Y (Twist)	0.7868
Moment Z	39.9689

Worst Case Reactions ASD

These results are taken from the worst case values in the above table and are used in the Soil Checks in the Foundation Module.
Note: Worst case values are assumed as downforce wind load cases.

Result	Value (kip, kip-ft)
Axial	5.3482
Shear X	-2.5934
Shear Z	-0.1720
Moment X	-0.3910
Moment Y (Twist)	0.4614
Moment Z	23.7188

Reaction Forces for Foundation 2 (Node ID#101), (kip, kip-ft)

ASD Load Combination Results

Name	Fx	Fy	Fz	Mx	My	Mz
ULS: 1. D	-0.0000	1.4699	0.0294	0.0682	-0.0625	0.0161
ULS: 2. D + L	-0.0000	1.4699	0.0294	0.0682	-0.0625	0.0161
ULS: 3. D + (S or Lr or R)	-0.0000	4.0475	0.0996	0.2312	-0.2115	0.0283
ULS: 3. D + (S or Lr or R)	-0.0000	1.4699	0.0294	0.0682	-0.0625	0.0161
ULS: 4. D + 0.75L + 0.75(S or Lr or R)	-0.0000	3.4031	0.0820	0.1904	-0.1742	0.0253
ULS: 4. D + 0.75L + 0.75(S or Lr or R)	-0.0000	1.4699	0.0294	0.0682	-0.0625	0.0161
ULS: 5b. D + 0.7E	-0.0000	1.4699	0.0294	0.0682	-0.0625	0.0161

Name	Fx	Fy	Fz	Mx	My	Mz
ULS: 6b. D + 0.75L + 0.75(0.7)E + 0.75S	-0.0000	3.4031	0.0820	0.1904	-0.1742	0.0253
ULS: 8. 0.6D + 0.7E	-0.0000	0.8820	0.0176	0.0409	-0.0375	0.0096
ULS: 5a. D + 0.6W_Wind downforce Case A only	-2.5934	4.0633	0.1494	0.3356	-0.4453	23.7188
ULS: 5a. D + 0.6W_Wind downforce Case B only	-2.5934	4.0633	0.1494	0.3356	-0.4453	23.7188
ULS: 5a. D + 0.6W_Wind uplift Case A only	1.8761	-0.4062	-0.0571	-0.1242	0.2142	-15.5307
ULS: 5a. D + 0.6W_Wind uplift Case B only	1.6554	-0.1854	-0.0475	-0.1027	0.1832	-18.8498
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case A only	-1.9450	5.3482	0.1720	0.3910	-0.4614	17.8023
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case B only	-1.9450	5.3482	0.1720	0.3910	-0.4614	17.8023
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case A only	1.4071	1.9961	0.0171	0.0461	0.0333	-11.6348
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case B only	1.2415	2.1616	0.0244	0.0622	0.0101	-14.1241
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case A only	-1.9450	3.4150	0.1194	0.2688	-0.3496	17.7931
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind downforce Case B only	-1.9450	3.4150	0.1194	0.2688	-0.3496	17.7931
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case A only	1.4071	0.0629	-0.0355	-0.0761	0.1450	-11.6440
ULS: 6a. D + 0.75L + 0.75(0.6)W + 0.75(S or Lr or R)_Wind uplift Case B only	1.2415	0.2284	-0.0282	-0.0600	0.1218	-14.1333
ULS: 7. 0.6D + 0.6W_Wind downforce Case A only	-2.5934	3.4753	0.1376	0.3083	-0.4203	23.7124
ULS: 7. 0.6D + 0.6W_Wind downforce Case B only	-2.5934	3.4753	0.1376	0.3083	-0.4203	23.7124
ULS: 7. 0.6D + 0.6W_Wind uplift Case A only	1.8761	-0.9941	-0.0689	-0.1515	0.2392	-15.5371
ULS: 7. 0.6D + 0.6W_Wind uplift Case B only	1.6554	-0.7734	-0.0592	-0.1300	0.2082	-18.8562

Worst Case Reactions LRFD

These calculations are taken directly from the FEA via SkyCiv and are used in the Concrete Checks of the Foundation Module.
Note: Worst case values are assumed as downforce wind load cases.

Result	Value (kip, kip-ft)
Axial	8.0493
Shear X	-4.3223
Shear Z	0.2705
Moment X	0.6098
Moment Y (Twist)	0.7869
Moment Z	39.9696

Worst Case Reactions ASD

These results are taken from the worst case values in the above table and are used in the Soil Checks in the Foundation Module.
Note: Worst case values are assumed as downforce wind load cases.

Result	Value (kip, kip-ft)
Axial	5.3482
Shear X	-2.5934
Shear Z	0.1720
Moment X	0.3910
Moment Y (Twist)	0.4614
Moment Z	23.7188

Project Details

Design Code: AISC 360-16 LRFD
 Provision: LRFD
 Country: United States

User Name: sales@mtsolar.us
 Project Name: Wilkes_rev1
 Unit System: imperial



Design Input Information

Design Factors			
Φ_t	Φ_c	Φ_b	Φ_v
0.9	0.9	0.9	0.9

Design Materials			
ID	E (ksi)	F _y (ksi)	F _u (ksi)
1	29000	50	65

Section Dimensions

ID	Name	d (in)	t _w (in)				
1	2in Pipe Sch 40	2.38	0.15				
4	4in Pipe Sch 40	4.50	0.24				
8	6in Pipe Sch 80	6.63	0.43				

ID	Name	d (in)	b (in)	t _w (in)	t _b (in)	r (in)	
15	HSS5x3x1/8	5.00	3.00	0.12	0.12	0.12	

ID	Name	d (in)	t _w (in)	b _t (in)	b _b (in)	t _t (in)	t _b (in)	r (in)
18	W6x9	5.90	0.17	3.94	3.94	0.21	0.21	0.25

Section Properties								
ID	Name	A (in ²)	J (in ⁴)	I _{yp} (in ⁴)	I _{zp} (in ⁴)	I _w (in ⁶)	S _{yp} (in ³)	S _{zp} (in ³)
1	2in Pipe Sch 40	1.07	1.33	0.67	0.67	0.00	0.76	0.76
4	4in Pipe Sch 40	3.17	14.47	7.23	7.23	0.00	4.31	4.31

108	18	7.88	7.88	3.75	2.33,2.33,2.33,2.33,2.33,2.33,2.33,2.33,2.33,2.33,2.31,2.33,2.33,2.33,2.33,2.33,2.33,2.33,2.33,2.33,2.33,2.37,2.33,2.33,2.33,2.33	300	200	1
109	1	2.60	2.60	4.00	-	300	200	1
110	15	2.44	2.44	3.75	1.69,1.68,1.69,1.67,1.68,1.68,1.67,1.67,1.66,1.49,1.67,1.67,1.66,1.65,1.67,1.67,1.68,1.67,1.67,1.67,1.66,1.13,1.67,1.67,1.66,1.66	300	200	1
111	18	7.88	7.88	3.75	2.33,2.33	300	200	1
112	4	1.30	1.30	2.00	-	300	200	1
113	18	4.88	4.00	7.50	1.12,1.12,1.12,1.12,1.12,1.12,1.11,1.11,1.11,1.16,1.11,1.11,1.11,1.15,1.12,1.12,1.12,1.14,1.11,1.11,1.11,1.16,1.11,1.11,1.11,1.15	300	200	1
114	18	4.88	4.00	7.50	1.12,1.12,1.12,1.12,1.12,1.12,1.11,1.11,1.11,1.21,1.11,1.11,1.11,1.14,1.12,1.12,1.12,1.13,1.11,1.11,1.11,1.21,1.11,1.11,1.11,1.14	300	200	1
115	18	3.54	3.54	5.45	1.34,1.35,1.34,1.35,1.34,1.34,1.41,1.41,1.54,1.39,1.41,1.41,1.48,1.38,1.38,1.38,1.29,1.30,1.40,1.40,1.54,1.39,1.41,1.41,1.47,1.38	300	200	1
116	18	3.54	3.54	5.45	1.36,1.37,1.36,1.38,1.37,1.36,1.46,1.46,1.51,1.01,1.47,1.47,1.48,1.97,1.43,1.43,1.30,1.30,1.45,1.45,1.52,1.01,1.47,1.47,1.47,1.87	300	200	1

Member Design Capacity

Member ID	$\Phi_c P_n$ (kip)	$\Phi_t P_n$ (kip)	$\Phi_b M_{zn}$ (k-ft)	$\Phi_b M_{yn}$ (k-ft)	$\Phi_v V_{yn}$ (kip)	$\Phi_v V_{zn}$ (kip)
1	378.22	183.06	62.23	62.23	113.47	113.47
2	142.83	141.72	16.17	16.17	42.85	42.85
3	79.65	74.02	10.99	4.60	29.14	16.61
4	79.65	72.01	10.99	4.60	29.14	16.61
5	79.65	73.44	10.99	4.60	29.14	16.61
6	79.65	74.02	10.99	4.60	29.14	16.61
7	79.65	73.44	10.99	4.60	29.14	16.61
8	120.60	117.88	23.36	6.45	30.09	45.74
9	48.35	43.11	2.85	2.85	14.51	14.51
10	79.65	72.01	10.99	4.60	29.14	16.61
11	120.60	117.88	23.36	6.45	30.09	45.74
12	142.83	141.72	16.17	16.17	42.85	42.85
13	120.60	98.23	19.54	6.45	30.09	45.74
14	120.60	98.23	19.54	6.45	30.09	45.74
15	120.60	54.44	23.36	6.45	30.09	45.74
16	120.60	54.44	23.36	6.45	30.09	45.74
101	378.22	183.06	62.23	62.23	113.47	113.47
102	142.83	141.72	16.17	16.17	42.85	42.85
103	79.65	74.02	10.99	4.60	29.14	16.61
104	79.65	72.01	10.99	4.60	29.14	16.61
105	79.65	73.44	10.99	4.60	29.14	16.61
106	79.65	74.02	10.99	4.60	29.14	16.61
107	79.65	73.44	10.99	4.60	29.14	16.61
108	120.60	54.44	23.36	6.45	30.09	45.74
109	48.35	43.11	2.85	2.85	14.51	14.51
110	79.65	72.01	10.99	4.60	29.14	16.61
111	120.60	54.44	23.36	6.45	30.09	45.74
112	142.83	141.72	16.17	16.17	42.85	42.85
113	120.60	98.23	19.54	6.45	30.09	45.74
114	120.60	98.23	19.54	6.45	30.09	45.74

115	120.60	102.67	23.36	6.45	30.09	45.74
116	120.60	102.67	20.55	6.45	30.09	45.74


Design Ratio

Member ID	P	M _z	M _y	V _y	V _z	(P,M _z ,M _y)	Worst LC	KL/r	δ	Status
1	0.044	0.642	0.028	0.038	0.002	0.672	#13	0.498	Not Required	Pass
2	0.001	0.433	0.291	0.099	0.054	0.716	#13	0.052	Not Required	Pass
3	0.014	0.775	0.184	0.079	0.028	0.878	#13	0.044	Not Required	Pass
4	0.014	0.703	0.267	0.071	0.034	0.790	#21	0.078	Not Required	Pass
5	0.014	0.481	0.285	0.077	0.040	0.513	#13	0.073	Not Required	Pass
6	0.013	0.663	0.121	0.066	0.015	0.713	#13	0.044	Not Required	Pass
7	0.012	0.412	0.189	0.066	0.027	0.427	#13	0.073	Not Required	Pass
8	0.001	0.040	0.085	0.031	0.010	0.103	#21	0.088	Not Required	Pass
9	0.005	0.063	0.077	0.002	0.002	0.140	#13	0.198	Not Required	Pass
10	0.011	0.596	0.220	0.060	0.031	0.728	#21	0.078	Not Required	Pass
11	0.002	0.043	0.087	0.035	0.010	0.108	#21	0.059	Not Required	Pass
12	0.002	0.335	0.242	0.082	0.047	0.561	#13	0.052	Not Required	Pass
13	0.006	0.216	0.299	0.051	0.015	0.480	#21	0.177	Not Required	Pass
14	0.006	0.203	0.299	0.046	0.015	0.470	#21	0.177	Not Required	Pass
15	0.000	0.084	0.139	0.035	0.010	0.210	#21	Not Required	Not Required	Pass
16	0.000	0.076	0.139	0.031	0.010	0.206	#21	Not Required	Not Required	Pass
101	0.044	0.642	0.028	0.038	0.002	0.672	#13	0.498	Not Required	Pass
102	0.002	0.335	0.242	0.082	0.047	0.561	#13	0.052	Not Required	Pass
103	0.013	0.663	0.121	0.066	0.015	0.713	#13	0.044	Not Required	Pass
104	0.011	0.596	0.220	0.060	0.031	0.728	#21	0.078	Not Required	Pass
105	0.012	0.412	0.189	0.066	0.027	0.427	#13	0.073	Not Required	Pass
106	0.014	0.775	0.184	0.079	0.028	0.878	#13	0.044	Not Required	Pass
107	0.014	0.481	0.285	0.077	0.040	0.513	#13	0.073	Not Required	Pass
108	0.000	0.076	0.139	0.031	0.010	0.206	#21	Not Required	Not Required	Pass
109	0.005	0.063	0.077	0.002	0.002	0.140	#13	0.198	Not Required	Pass
110	0.014	0.703	0.267	0.071	0.034	0.790	#21	0.078	Not Required	Pass
111	0.000	0.084	0.139	0.035	0.010	0.210	#21	Not Required	Not Required	Pass
112	0.001	0.433	0.291	0.099	0.054	0.716	#13	0.052	Not Required	Pass
113	0.006	0.216	0.299	0.051	0.015	0.480	#21	0.177	Not Required	Pass
114	0.006	0.203	0.299	0.046	0.015	0.470	#21	0.265	Not Required	Pass
115	0.002	0.043	0.114	0.035	0.010	0.149	#21	0.156	Not Required	Pass
116	0.001	0.040	0.113	0.031	0.010	0.144	#21	0.235	Not Required	Pass

Definitions

Φ _t	Safety factor for tensile
Φ _c	Safety factor for compression
Φ _b	Safety factor for flexure
Φ _v	Safety factor for shear
E	Modulus of elasticity
F _y	Specified minimum yield stress
F _u	Specified minimum tensile strength
A	Cross-sectional area
J	Torsional constant
I _{yp}	Moment of inertia about the Y axes
I _{zp}	Moment of inertia about the Z axes
I _w	Warping constant
S _{yp}	Plastic section modulus about the Y axis
S _{zp}	Plastic section modulus about the Z axis
KL	Effective length
C _n	Buckling modification factor (from all load combinations)

L_b	Length between braced points
LST	Limited slenderness for tension
LSC	Limited slenderness for compression
LD	Limited deflection
P_n	Nominal axial strength (tension/compression)
M_n	Nominal flexural strength (about Z/Y axis)
V_n	Nominal shear strength (along Z/Y axis)
P	Design ratio in case of axial force
M_z	Design ratio in case of bending about Z axis
M_y	Design ratio in case of bending about Y axis
V_y	Design ratio in case of shear along Y axis
V_z	Design ratio in case of shear along Z axis
(P, M_z , M_y)	Design ratio in case of axial force and bending action
KL/r	Design ratio in case of section slenderness
δ	Design ratio in case of member deflection
OK	Capacity is provided
NG	Capacity is not provided

REFERENCES	CALCULATIONS	RESULTS																										
	<p>SkyCiv Foundation Design Pile Foundation</p> <p>Design Information : Design code : IBC 2021 (International Building Code) Unit System : Imperial</p>																											
	<p>Pile Input</p>  <p>Geometry Pile shape: round $D = 36$ in - Pile diameter $L = 8.25$ ft - Total pile length $h_1 = 0$ ft - Lateral load height from the top of the pile, $h_2 = 0$ ft - Depth to resisting surface $h_e = 0$ ft - Length of pile above the ground</p> <p>Tabulation of Soil Parameters</p> <table border="1" data-bbox="416 1077 1193 1171"> <thead> <tr> <th>Layer</th> <th>Label</th> <th>Allowable Bearing Pressure (q_a) (psf)</th> <th>Allowable Lateral Pressure (R) (psf/ft)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Sand, silty sand, clayey sand, silty gravel & clayey gravel</td> <td>2000.000</td> <td>150.000</td> </tr> </tbody> </table> <p>Tabulation of Loads</p> <table border="1" data-bbox="676 1263 935 1435"> <thead> <tr> <th>Load Component</th> <th>ASD</th> <th>LRFD</th> </tr> </thead> <tbody> <tr> <td>P (kip)</td> <td>5.348</td> <td>8.049</td> </tr> <tr> <td>V_x (kip)</td> <td>-2.593</td> <td>-4.322</td> </tr> <tr> <td>V_z (kip)</td> <td>-0.172</td> <td>-0.271</td> </tr> <tr> <td>M_x (kipft)</td> <td>-0.391</td> <td>-0.610</td> </tr> <tr> <td>M_z (kipft)</td> <td>23.719</td> <td>39.969</td> </tr> </tbody> </table> <p>Material Properties $f'_{ck} = 2.5$ ksi - Concrete strength,</p>	Layer	Label	Allowable Bearing Pressure (q_a) (psf)	Allowable Lateral Pressure (R) (psf/ft)	1	Sand, silty sand, clayey sand, silty gravel & clayey gravel	2000.000	150.000	Load Component	ASD	LRFD	P (kip)	5.348	8.049	V_x (kip)	-2.593	-4.322	V_z (kip)	-0.172	-0.271	M_x (kipft)	-0.391	-0.610	M_z (kipft)	23.719	39.969	
Layer	Label	Allowable Bearing Pressure (q_a) (psf)	Allowable Lateral Pressure (R) (psf/ft)																									
1	Sand, silty sand, clayey sand, silty gravel & clayey gravel	2000.000	150.000																									
Load Component	ASD	LRFD																										
P (kip)	5.348	8.049																										
V_x (kip)	-2.593	-4.322																										
V_z (kip)	-0.172	-0.271																										
M_x (kipft)	-0.391	-0.610																										
M_z (kipft)	23.719	39.969																										
	<p>Required depth to resist lateral loads (ASD) H - Point of application of the lateral load</p> $H = h_1 + h_2 + h_e$ $H = (0 \text{ ft}) + (0 \text{ ft}) + (0 \text{ ft})$ $H = 0 \text{ ft}$ <p>Considering x-direction: H_o - Lateral force per length of pile,</p> $H_o = \frac{V_x}{D}$ $H_o = \frac{(-2.593 \text{ kip})}{(36 \text{ in})}$ $H_o = -0.86433 \text{ kip/ft}$ <p>M_o - Moment per length of pile,</p> $M_o = \frac{M_x + (V_x H)}{D}$																											

$$M_o = \frac{(23.719 \text{ kipft}) + ((-2.593 \text{ kip}) \times (0 \text{ ft}))}{(36 \text{ in})}$$

$$M_o = 7.9063 \text{ kipft/ft}$$

Required depth of embedment in earth:

$$L_x^3 - \left(14.14 \times \frac{H_o \times L_x}{R}\right) - \left(18.85 \times \frac{M_o}{R}\right) = 0$$

Solving the cubic equation:

$L_{e,x} = 7.3403 \text{ ft}$ - Required depth in x-direction,

Considering z-direction:

H_o - Lateral force per length of pile,

$$H_o = \frac{V_z}{D}$$

$$H_o = \frac{(-0.172 \text{ kip})}{(36 \text{ in})}$$

$$H_o = -0.057333 \text{ kip/ft}$$

M_o - Moment per length of pile,

$$M_o = \frac{M_x + (V_z H)}{D}$$

$$M_o = \frac{(0.391 \text{ kipft}) + ((-0.172 \text{ kip}) \times (0 \text{ ft}))}{(36 \text{ in})}$$

$$M_o = 0.13033 \text{ kipft/ft}$$

Required depth of embedment in earth:

$$L_z^3 - \left(14.14 \times \frac{H_o \times L_z}{R}\right) - \left(18.85 \times \frac{M_o}{R}\right) = 0$$

Solving the cubic equation:

$L_{e,z} = 1.8531 \text{ ft}$ - Required depth in z-direction,

Minimum embedded depth required:

$L_{e,req}$ - Depth of pile required,

$$L_{e,req} = \text{MAX}[L_{e,x}, L_{e,z}]$$

$$L_{e,req} = \text{MAX}[(7.3403 \text{ ft}), (1.8531 \text{ ft})]$$

$$L_{e,req} = 7.34 \text{ ft}$$

L_e - Actual embedded length of pile,

$$L_e = L - h_c - h_2$$

$$L_e = (8.25 \text{ ft}) - (0 \text{ ft}) - (0 \text{ ft})$$

$$L_e = 8.25 \text{ ft}$$

Ratio - Embedded depth

$$\text{Ratio} = \frac{L_{e,req}}{L_e}$$

$$\text{Ratio} = \frac{(7.34 \text{ ft})}{(8.25 \text{ ft})}$$

$$\text{Ratio} = 0.8897$$

Status: **PASS**
Ratio: **0.890**

End-bearing Capacity (ASD)

A - Pile cross-section area

$$A = \pi \left(\frac{D}{2}\right)^2$$

$$A = \pi \times \left(\frac{(36 \text{ in})}{2}\right)^2$$

$$A = 7.0686 \text{ ft}^2$$

q - End-bearing pressure

$$q = \frac{P_c}{A}$$

$$q = \frac{(5.348 \text{ kip})}{(7.0686 \text{ ft}^2)}$$

$$q = 0.75659 \text{ kip/ft}^2$$

Check bearing capacity ratio:

Ratio - Capacity

$$\text{Ratio} = \frac{q}{q_a}$$

$$\text{Ratio} = \frac{(0.75659 \text{ kip/ft}^2)}{(2000 \text{ psf})}$$

$$\text{Ratio} = 0.37829$$

Status: **PASS**
Ratio: **0.380**

Czerniak

Lateral Soil Pressure (ASD):

L/D - Length to least lateral dimension ratio,

$$L/D = \frac{L}{D}$$

$$L/D = \frac{(8.25 \text{ ft})}{(36 \text{ in})}$$

$$L/D = 2.75$$

Since $L/D \leq 10$,

Pile is short.

Considering x-direction:

$H_o = -0.86433 \text{ kip/ft}$ - Lateral force per length of pile,

$M_o = 7.9063 \text{ kipft/ft}$ - Overturning moment per length of pile,

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (7.9063 \text{ kipft/ft}) \times (8.25 \text{ ft})) + (3 \times (-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft})^2)}{(6 \times (7.9063 \text{ kipft/ft})) + (4 \times (-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft}))}$$

$$a = 5.7582 \text{ ft}$$

p - Earth pressure against the pile at distance $a/2$ from resting surface,

$$p = \frac{1.178 [(4 M_o) + (3 H_o L_e)]^2}{L_e^2 [(3 M_o) + (2 H_o L_e)]}$$

$$p = \frac{1.178 \times [(4 \times (7.9063 \text{ kipft/ft})) + (3 \times (-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft}))]^2}{(8.25 \text{ ft})^2 \times [(3 \times (7.9063 \text{ kipft/ft})) + (2 \times (-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft}))]}$$

$$p = 0.19163 \text{ kip/ft}^2$$

s - Earth pressure against the pile at distance L_e ,

$$s = \frac{9.425 [(2 M_o) + (H_o L_e)]}{L_e^2}$$

$$s = \frac{9.425 \times [(2 \times (7.9063 \text{ kipft/ft})) + ((-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft}))]}{(8.25 \text{ ft})^2}$$

$$s = 1.2022 \text{ kip/ft}^2$$

Check lateral soil pressure capacity:

p_a - Allowable lateral soil pressure at depth $a/2$,

$$p_a = R \frac{a}{2}$$

$$p_a = (150 \text{ psf/ft}) \times \frac{(5.7582 \text{ ft})}{2}$$

$$p_a = 0.43186 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity

$$\text{Ratio} = \frac{p}{p_a}$$

$$\text{Ratio} = \frac{(0.19163 \text{ kip/ft}^2)}{(0.43186 \text{ kip/ft}^2)}$$

$$\text{Ratio} = 0.44374$$

Status: **PASS**
Ratio: **0.440**

p_s - Allowable lateral soil pressure at depth L_e ,

$$p_s = R L_e$$

$$p_s = (150 \text{ psf/ft}) \times (8.25 \text{ ft})$$

$$p_s = 1.2375 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity

$$\text{Ratio} = \frac{s}{p_s}$$

$$\text{Ratio} = \frac{(1.2022 \text{ kip/ft}^2)}{(1.2375 \text{ kip/ft}^2)}$$

$$\text{Ratio} = 0.9715$$

Status: **PASS**
Ratio: **0.970**

Considering z-direction:

$H_o = -0.057333 \text{ kip/ft}$ - Lateral force per length of pile,

$M_o = 0.13033 \text{ kipft/ft}$ - Overturning moment per length of pile,

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (0.13033 \text{ kipft/ft}) \times (8.25 \text{ ft})) + (3 \times (-0.057333 \text{ kip/ft}) \times (8.25 \text{ ft})^2)}{(6 \times (0.13033 \text{ kipft/ft})) + (4 \times (-0.057333 \text{ kip/ft}) \times (8.25 \text{ ft}))}$$

$$a = 5.9864 \text{ ft}$$

p - Earth pressure against the pile at distance $a/2$ from resting surface,

$$p = \frac{1.178 [(4 M_o) + (3 H_o L_e)]^2}{L_e^2 [(3 M_o) + (2 H_o L_e)]}$$

$$p = \frac{1.178 \times [(4 \times (0.13033 \text{ kipft/ft})) + (3 \times (-0.057333 \text{ kip/ft}) \times (8.25 \text{ ft}))]^2}{(8.25 \text{ ft})^2 \times [(3 \times (0.13033 \text{ kipft/ft})) + (2 \times (-0.057333 \text{ kip/ft}) \times (8.25 \text{ ft}))]}$$

$$p = -0.025129 \text{ kip/ft}^2$$

s - Earth pressure against the pile at distance L_e ,

$$s = \frac{9.425 [(2 M_o) + (H_o L_e)]}{L_e^2}$$

$$s = \frac{9.425 \times [(2 \times (0.13033 \text{ kipft/ft})) + ((-0.057333 \text{ kip/ft}) \times (8.25 \text{ ft}))]}{(8.25 \text{ ft})^2}$$

$$s = -0.029403 \text{ kip/ft}^2$$

Check lateral soil pressure capacity:

p_a - Allowable lateral soil pressure at depth $a/2$,

$$p_a = R \frac{a}{2}$$

$$p_a = (150 \text{ psf/ft}) \times \frac{(5.9864 \text{ ft})}{2}$$

$$p_a = 0.44898 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity

$$\text{Ratio} = \frac{p}{p_a}$$

$$\text{Ratio} = \frac{(-0.025129 \text{ kip/ft}^2)}{(0.44898 \text{ kip/ft}^2)}$$

$$\text{Ratio} = -0.055969$$

p_s - Allowable lateral soil pressure at depth L_e ,

$$p_s = R L_e$$

$$p_s = (150 \text{ psf/ft}) \times (8.25 \text{ ft})$$

$$p_s = 1.2375 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity


Status: **PASS**
Ratio: **-0.060**

$$ratio = \frac{-}{p_s}$$

$$Ratio = \frac{(-0.029403 \text{ kip/ft}^2)}{(1.2375 \text{ kip/ft}^2)}$$

$$Ratio = -0.02376$$

Status: **PASS**
Ratio: **-0.020**



Shear force and Bending moment (x-direction, LRFD)

H_o - Lateral force per length of pile,

$$H_o = \frac{V_z}{D}$$

$$H_o = \frac{(-4.322 \text{ kip})}{(36 \text{ in})}$$

$$H_o = -1.4407 \text{ kip/ft}$$

M_o - Moment per length of pile,

$$M_o = \frac{M_z + (V_z H)}{D}$$

$$M_o = \frac{(39.97 \text{ kipft}) + ((-4.322 \text{ kip}) \times (0 \text{ ft}))}{(36 \text{ in})}$$

$$M_o = 13.323 \text{ kipft/ft}$$

E - Distance from lateral load to resisting surface,

$$E = \frac{M_o}{H_o}$$

$$E = \frac{(13.323 \text{ kipft/ft})}{(-1.4407 \text{ kip/ft})}$$

$$E = 9.2478 \text{ ft}$$

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (13.323 \text{ kipft/ft}) \times (8.25 \text{ ft})) + (3 \times (-1.4407 \text{ kip/ft}) \times (8.25 \text{ ft})^2)}{(6 \times (13.323 \text{ kipft/ft})) + (4 \times (-1.4407 \text{ kip/ft}) \times (8.25 \text{ ft}))}$$

$$a = 5.7564 \text{ ft}$$

V_{max} - Max shear force located at depth a ,

$$V_{max} = (H_o D) \left[1 - \left[3 \left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{L_e} \right)^2 + 4 \left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{L_e} \right)^3 \right] \right]$$

$$V_{max} = ((-1.4407 \text{ kip/ft}) \times (36 \text{ in})) \times \left[1 - \left[3 \times \left(\frac{4 \times (9.2478 \text{ ft})}{(8.25 \text{ ft})} + 3 \right) \times \left(\frac{(5.7564 \text{ ft})}{(8.25 \text{ ft})} \right)^2 + 4 \times \left(\frac{3 \times (9.2478 \text{ ft})}{(8.25 \text{ ft})} + 2 \right) \times \left(\frac{(5.7564 \text{ ft})}{(8.25 \text{ ft})} \right)^3 \right] \right]$$

$$V_{max} = 11.425 \text{ kip}$$

M_{max} - Max bending moment located at depth $a/2$,

$$M_{max} = (H_o D L_e) \left[\left(\frac{E}{L_e} + \frac{a}{2 L_e} \right) - \left[\left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{2 L_e} \right)^3 + \left[\left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{2 L_e} \right)^4 \right] \right] \right]$$

$$M_{max} = ((-1.4407 \text{ kip/ft}) \times (36 \text{ in}) \times (8.25 \text{ ft})) \times \left[\left(\frac{(9.2478 \text{ ft})}{(8.25 \text{ ft})} + \frac{(5.7564 \text{ ft})}{2 \times (8.25 \text{ ft})} \right) - \left[\left(\frac{4 \times (9.2478 \text{ ft})}{(8.25 \text{ ft})} + 3 \right) \times \left(\frac{(5.7564 \text{ ft})}{2 \times (8.25 \text{ ft})} \right)^3 + \left[\left(\frac{3 \times (9.2478 \text{ ft})}{(8.25 \text{ ft})} + 2 \right) \times \left(\frac{(5.7564 \text{ ft})}{2 \times (8.25 \text{ ft})} \right)^4 \right] \right] \right]$$

$$M_{max} = 43.91 \text{ kipft}$$

Shear force and Bending moment (z-direction, LRFD)

H_o - Lateral force per length of pile,

$$H_o = \frac{V_z}{D}$$

$$H_o = \frac{(-0.271 \text{ kip})}{(36 \text{ in})}$$

$$H_o = -0.090333 \text{ kip/ft}$$

M_o - Moment per length of pile,

$$M_o = \frac{M_x + (V_z H)}{D}$$

$$M_o = \frac{(0.61 \text{ kipft}) + ((-0.271 \text{ kip}) \times (0 \text{ ft}))}{(36 \text{ in})}$$

$$M_o = 0.20333 \text{ kipft/ft}$$

E - Distance from lateral load to resisting surface,

$$E = \frac{M_o}{H_o}$$

$$E = \frac{(0.20333 \text{ kipft/ft})}{(-0.090333 \text{ kip/ft})}$$

$$E = 2.2509 \text{ ft}$$

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (0.20333 \text{ kipft/ft}) \times (8.25 \text{ ft})) + (3 \times (-0.090333 \text{ kip/ft}) \times (8.25 \text{ ft})^2)}{(6 \times (0.20333 \text{ kipft/ft})) + (4 \times (-0.090333 \text{ kip/ft}) \times (8.25 \text{ ft}))}$$

$$a = 5.9878 \text{ ft}$$

V_{max} - Max shear force located at depth a ,

$$V_{max} = (H_o b) \left[1 - \left[3 \left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{L_e} \right)^2 + 4 \left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{L_e} \right)^3 \right] \right]$$

$$V_{max} = ((-0.090333 \text{ kip/ft}) \times (36 \text{ in})) \times \left[1 - \left[3 \times \left(\frac{4 \times (2.2509 \text{ ft})}{(8.25 \text{ ft})} + 3 \right) \times \left(\frac{(5.9878 \text{ ft})}{(8.25 \text{ ft})} \right)^2 + 4 \times \left(\frac{3 \times (2.2509 \text{ ft})}{(8.25 \text{ ft})} + 2 \right) \times \left(\frac{(5.9878 \text{ ft})}{(8.25 \text{ ft})} \right)^3 \right] \right]$$

$$V_{max} = 0.31308 \text{ kip}$$

M_{max} - Max bending moment located at depth $a/2$,

$$M_{max} = (H_o b L_e) \left[\left(\frac{E}{L_e} + \frac{a}{2 L_e} \right) - \left[\left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{2 L_e} \right)^3 + \left[\left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{2 L_e} \right)^4 \right] \right] \right]$$

$$M_{max} = ((-0.090333 \text{ kip/ft}) \times (36 \text{ in}) \times (8.25 \text{ ft})) \times \left[\left(\frac{(2.2509 \text{ ft})}{(8.25 \text{ ft})} + \frac{(5.9878 \text{ ft})}{2 \times (8.25 \text{ ft})} \right) - \left[\left(\frac{4 \times (2.2509 \text{ ft})}{(8.25 \text{ ft})} + 3 \right) \times \left(\frac{(5.9878 \text{ ft})}{2 \times (8.25 \text{ ft})} \right)^3 + \left[\left(\frac{3 \times (2.2509 \text{ ft})}{(8.25 \text{ ft})} + 2 \right) \times \left(\frac{(5.9878 \text{ ft})}{2 \times (8.25 \text{ ft})} \right)^4 \right] \right] \right]$$

$$M_{max} = 1.0935 \text{ kipft}$$

Minimum Reinforcement Check (LRFD)

Parameters:

- $f'_{ck} = 2.5 \text{ ksi}$ - Concrete strength,
 $f_{yk} = 60 \text{ ksi}$ - Longitudinal reinforcement strength,
 $\phi = 0.65$ - Reduction factor for axial strength,
 $\alpha = 0.85$ - Alpha factor for axial strength,
 $A_g = 1017.9 \text{ in}^2$ - Gross area of concrete,

Table 22.4.2.1

Longitudinal reinforcement:

Required reinforcement due to axial load, $A_{st,required}$

22.4.2.2, 10.6.1.1

$A_{st,required}$

$$A_{st,required} = \text{Min} \left[\frac{\frac{P}{\phi \alpha} - (0.85 f'_{ck} A_g)}{f_{yk} - (0.85 f'_{ck})}, (0.08 A_g) \right]$$

$$A_{st,required} = \text{Min} \left[\frac{\frac{(8.049 \text{ kip})}{(0.65) \times (0.85)} - (0.85 \times (2.5 \text{ ksi}) \times (1017.9 \text{ in}^2))}{(60 \text{ ksi}) - (0.85 \times (2.5 \text{ ksi}))}, (0.08 \times (1017.9 \text{ in}^2)) \right]$$

$$A_{st,required} = -37.122 \text{ in}^2$$

A_{min} - Governing minimum reinforcement area,

$$A_{min} = \text{Max} [A_{st,required}, (0.0018 A_g)]$$

$$A_{min} = \text{Max} [(-37.122 \text{ in}^2), (0.0018 \times (1017.9 \text{ in}^2))]$$

$$A_{min} = 1.8322 \text{ in}^2$$

n_{rebar} - Required number of reinforcement,

$$n_{rebar} = \frac{A_{min}}{A_{rebar}}$$

$$n_{rebar} = \frac{(1.8322 \text{ in}^2)}{(0.3068 \text{ in}^2)}$$

$$n_{rebar} = 6$$

A_{st} - Actual total reinforcement area,

$$A_{st} = n_{rebar} \frac{\pi d_{bar}^2}{4}$$

$$A_{st} = (6) \times \frac{\pi \times (0.625 \text{ in})^2}{4}$$

$$A_{st} = 1.8408 \text{ in}^2$$

Ratio - Capacity

$$\text{Ratio} = \frac{A_{min}}{A_{st}}$$

$$\text{Ratio} = \frac{(1.8322 \text{ in}^2)}{(1.8408 \text{ in}^2)}$$

$$\text{Ratio} = 0.99533$$

25.2.3

s_{rebar} - Minimum spacing of reinforcement,

$$s_{rebar} = \text{Max} [1.5, (1.5 d_{bar})]$$

$$s_{rebar} = \text{Max} [1.5, (1.5 \times (0.625 \text{ in}))]$$

$$s_{rebar} = 1.5 \text{ in}$$

Ties:

25.7.2.2

Since longitudinal reinforcement is \leq No. 10 \varnothing : Use #3(0.375 in)

25.7.2.1

s_{ties} - Maximum center-to-center spacing of ties,

$$s_{ties} = \text{Min} [(16 d_{bar}), (48 d_{ties}), D]$$

$$s_{ties} = \text{Min} [(16 \times (0.625 \text{ in})), (48 \times (0.375 \text{ in})), (36 \text{ in})]$$

$$s_{ties} = 10 \text{ in}$$

Summary:

Status: **PASS**
Ratio: **1.000**

Main reinforcement: **6 - #5 (0.625 in)**
Ties: **#3(0.375 in) - 10 in**

Axial Compression Strength (ACI 318-19, LRFD)

22.4.2.2

ϕP_N - Allowable axial compressive strength

$$\phi P_N = \phi 0.85 [(0.85 f'_{ck} [A_g - A_{st}]) + (f_{yk} A_{st})]$$

$$\phi P_N = (0.65) \times 0.85 \times [(0.85 \times (2.5 \text{ ksi}) \times [(1017.9 \text{ in}^2) - (1.8408 \text{ in}^2)]) + ((60 \text{ ksi}) \times (1.8408 \text{ in}^2))]$$

$$\phi P_N = 1253.9 \text{ kip}$$

Ratio - Capacity

$$\text{Ratio} = \frac{P}{\phi P_N}$$

$$\text{Ratio} = \frac{(8.049 \text{ kip})}{(1253.9 \text{ kip})}$$

$$\text{Ratio} = 0.0064191$$

Status: **PASS**
Ratio: **0.010**

Shear Strength (ACI 318-19, LRFD)

Parameters:

22.5.2.2

$b_w = 36 \text{ in}$ - Effective width,
 d - Effective depth

$$d = 0.80 D$$

$$d = 0.80 \times (36 \text{ in})$$

$$d = 28.8 \text{ in}$$

22.5.5.1.3

λ_s - size effect modification factor

$$\lambda_s = \text{MIN} \left[\sqrt{\frac{2}{1 + \frac{d}{10}}}, 1 \right]$$

$$\lambda_s = \text{MIN} \left[\sqrt{\frac{2}{1 + \frac{(28.8 \text{ in})}{10}}}, 1 \right]$$

$$\lambda_s = 0.71796$$

22.5.5.1.1

The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$.
 $V_{c,max}$ - Max shear strength of concrete

$$V_{c,max} = 5 \lambda_s \sqrt{f'_{ck}} b_w d$$

$$V_{c,max} = 5 \times (0.71796) \times \sqrt{(2500 \text{ psi})} \times (36 \text{ in}) \times (28.8 \text{ in})$$

$$V_{c,max} = 186.09 \text{ kip}$$

22.5.5.1.1(a)

The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$, $P = 8.049 \text{ kip} \rightarrow 8049 \text{ lbf}$.
 $V_{c,a}$ - Shear strength of concrete (a)

$$V_{c,a} = \left[2 \lambda_s \sqrt{f'_{ck}} + \frac{P}{6 A_g} \right] b_w d$$

$$V_{c,a} = \left[2 \times (0.71796) \times \sqrt{(2500 \text{ psi})} + \frac{(8049 \text{ lbf})}{6 \times (1017.9 \text{ in}^2)} \right] \times (36 \text{ in}) \times (28.8 \text{ in})$$

$$V_{c,a} = 75.804 \text{ kip}$$

22.5.5.1.2

The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$.
 $V_{c,b}$ - Shear strength of concrete (b)

$$V_{c,b} = \left[2 \lambda_s \sqrt{f'_{ck}} + (0.05 f'_{ck}) \right] b_w d$$

$$V_{c,b} = \left[2 \times (0.71796) \times \sqrt{(2500 \text{ psi})} + (0.05 \times (2500 \text{ psi})) \right] \times (36 \text{ in}) \times (28.8 \text{ in})$$

$$V_{c,b} = 204.04 \text{ kip}$$


V_c - Governing shear strength of concrete

$$V_c = \text{Min}[V_{c,max}, V_{c,a}, V_{c,b}]$$

$$V_c = \text{Min}[(186.09 \text{ kip}), (75.804 \text{ kip}), (204.04 \text{ kip})]$$

<p>22.5.1.2</p> <p>22.5.8.5.3</p> <p>22.5.1.1</p>	<p style="text-align: center;">$V_c = 75.804 \text{ kip}$</p> <p>The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$.</p> <p>$V_{s,a}$ - Shear strength of steel (a)</p> $V_{s,a} = 8 \sqrt{f'_{ck}} b_w d$ $V_{s,a} = 8 \times \sqrt{(2500 \text{ psi})} \times (36 \text{ in}) \times (28.8 \text{ in})$ $V_{s,a} = 414.72 \text{ kip}$ <p>A_v - Ties rebar area,</p> $A_v = \frac{\pi d_{ties}^2}{4}$ $A_v = \frac{\pi \times (0.375 \text{ in})^2}{4}$ $A_v = 0.11045 \text{ in}^2$ <p>$V_{s,b}$ - Shear strength of steel (b)</p> $V_{s,b} = \frac{2 A_v f_{yw} d}{s_{ties}}$ $V_{s,b} = \frac{2 \times (0.11045 \text{ in}^2) \times (60 \text{ ksi}) \times (28.8 \text{ in})}{(10 \text{ in})}$ $V_{s,b} = 38.17 \text{ kip}$ <p>V_s - Governing shear strength of steel</p> $V_s = MIN[V_{s,a}, V_{s,b}]$ $V_s = MIN[(414.72 \text{ kip}), (38.17 \text{ kip})]$ $V_s = 38.17 \text{ kip}$ <p>ϕV_n - Allowable shear strength</p> $\phi V_n = \phi (V_c + V_s)$ $\phi V_n = (0.65) \times ((75.804 \text{ kip}) + (38.17 \text{ kip}))$ $\phi V_n = 74.084 \text{ kip}$ <p>Considering x-direction:</p> <p>$V_{max} = 11.425 \text{ kip}$ - Maximum shear force in the x-direction, Ratio - Capacity</p> $Ratio = \frac{V_{max}}{\phi V_n}$ $Ratio = \frac{(11.425 \text{ kip})}{(74.084 \text{ kip})}$ $Ratio = 0.15422$ <p>Considering z-direction:</p> <p>$V_{max} = 0.31308 \text{ kip}$ - Maximum shear force in the z-direction, Ratio - Capacity</p> $Ratio = \frac{V_{max}}{\phi V_n}$ $Ratio = \frac{(0.31308 \text{ kip})}{(74.084 \text{ kip})}$ $Ratio = 0.004226$	<p>Status: PASS Ratio: 0.150</p> <p>Status: PASS Ratio: 0.000</p>
	<p>Flexural Strength (ACI 318-19, LRFD)</p> <p>S_m - Section modulus</p> $S_m = \frac{\pi D^3}{32}$ $S_m = \frac{\pi \times (36 \text{ in})^3}{32}$	

<p>14.5.2.1b</p>	<p style="text-align: center;">$S_m = 4580.4 \text{ in}^3$</p> <p>$\lambda = 1$ - Concrete modification factor (Normal concrete), Allowable flexural strength: M_n shall be the lesser of: $\phi M_{n,1}$</p> $\phi M_{n,1} = \phi \times 5 \times \lambda \times \sqrt{f'_c} \times S_m$ $\phi M_{n,1} = 0.65 \times 5 \times 1 \times \sqrt{2.5 \text{ ksi}} \times 4580.442 \text{ in}^3$ $\phi M_{n,1} = 62.027 \text{ kipft}$ <p>$\phi M_{n,2}$</p> $\phi M_{n,2} = \phi \times 0.85 \times f'_c \times S_m$ $\phi M_{n,2} = (0.65) \times 0.85 \times (2.5 \text{ ksi}) \times (4580.4 \text{ in}^3)$ $\phi M_{n,2} = 527.23 \text{ kipft}$ <p>Therefore, ϕM_n - Allowable flexural strength,</p> $\phi M_n = \text{MIN}[\phi M_{n,1}, \phi M_{n,2}]$ $\phi M_n = \text{MIN}[(62.027 \text{ kipft}), (527.23 \text{ kipft})]$ $\phi M_n = 62.027 \text{ kipft}$ <p>Considering x-direction: $M_{max} = 43.91 \text{ kipft}$ - Maximum moment in the x-direction, Ratio - Capacity</p> $\text{Ratio} = \frac{M_{max}}{\phi M_n}$ $\text{Ratio} = \frac{(43.91 \text{ kipft})}{(62.027 \text{ kipft})}$ $\text{Ratio} = 0.70793$	<p>Status: PASS Ratio: 0.710</p>
	<p>Considering z-direction: $M_{max} = 1.0935 \text{ kipft}$ - Maximum moment in the z-direction, Ratio - Capacity</p> $\text{Ratio} = \frac{M_{max}}{\phi M_n}$ $\text{Ratio} = \frac{(1.0935 \text{ kipft})}{(62.027 \text{ kipft})}$ $\text{Ratio} = 0.017629$	<p>Status: PASS Ratio: 0.020</p>

REFERENCES	CALCULATIONS	RESULTS																										
	<p>SkyCiv Foundation Design Pile Foundation</p> <p>Design Information : Design code : IBC 2021 (International Building Code) Unit System : Imperial</p>																											
	<p>Pile Input</p>  <p>Geometry Pile shape: round $D = 36$ in - Pile diameter $L = 8.25$ ft - Total pile length $h_1 = 0$ ft - Lateral load height from the top of the pile, $h_2 = 0$ ft - Depth to resisting surface $h_e = 0$ ft - Length of pile above the ground</p> <p>Tabulation of Soil Parameters</p> <table border="1" data-bbox="414 1075 1189 1176"> <thead> <tr> <th>Layer</th> <th>Label</th> <th>Allowable Bearing Pressure (q_a) (psf)</th> <th>Allowable Lateral Pressure (R) (psf/ft)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Sand, silty sand, clayey sand, silty gravel & clayey gravel</td> <td>2000.000</td> <td>150.000</td> </tr> </tbody> </table> <p>Tabulation of Loads</p> <table border="1" data-bbox="670 1265 933 1433"> <thead> <tr> <th>Load Component</th> <th>ASD</th> <th>LRFD</th> </tr> </thead> <tbody> <tr> <td>P (kip)</td> <td>5.348</td> <td>8.049</td> </tr> <tr> <td>V_x (kip)</td> <td>-2.593</td> <td>-4.322</td> </tr> <tr> <td>V_z (kip)</td> <td>0.172</td> <td>0.271</td> </tr> <tr> <td>M_x (kipft)</td> <td>0.391</td> <td>0.610</td> </tr> <tr> <td>M_z (kipft)</td> <td>23.719</td> <td>39.970</td> </tr> </tbody> </table> <p>Material Properties $f'_{ck} = 2.5$ ksi - Concrete strength,</p>	Layer	Label	Allowable Bearing Pressure (q_a) (psf)	Allowable Lateral Pressure (R) (psf/ft)	1	Sand, silty sand, clayey sand, silty gravel & clayey gravel	2000.000	150.000	Load Component	ASD	LRFD	P (kip)	5.348	8.049	V_x (kip)	-2.593	-4.322	V_z (kip)	0.172	0.271	M_x (kipft)	0.391	0.610	M_z (kipft)	23.719	39.970	
Layer	Label	Allowable Bearing Pressure (q_a) (psf)	Allowable Lateral Pressure (R) (psf/ft)																									
1	Sand, silty sand, clayey sand, silty gravel & clayey gravel	2000.000	150.000																									
Load Component	ASD	LRFD																										
P (kip)	5.348	8.049																										
V_x (kip)	-2.593	-4.322																										
V_z (kip)	0.172	0.271																										
M_x (kipft)	0.391	0.610																										
M_z (kipft)	23.719	39.970																										
	<p>Required depth to resist lateral loads (ASD) H - Point of application of the lateral load</p> $H = h_1 + h_2 + h_e$ $H = (0 \text{ ft}) + (0 \text{ ft}) + (0 \text{ ft})$ $H = 0 \text{ ft}$ <p>Considering x-direction: H_o - Lateral force per length of pile,</p> $H_o = \frac{V_x}{D}$ $H_o = \frac{(-2.593 \text{ kip})}{(36 \text{ in})}$ $H_o = -0.86433 \text{ kip/ft}$ <p>M_o - Moment per length of pile,</p> $M_o = \frac{M_x + (V_x H)}{D}$																											

$$M_o = \frac{(23.719 \text{ kipft}) + ((-2.593 \text{ kip}) \times (0 \text{ ft}))}{(36 \text{ in})}$$

$$M_o = 7.9063 \text{ kipft/ft}$$

Required depth of embedment in earth:

$$L_x^3 - \left(14.14 \times \frac{H_o \times L_x}{R}\right) - \left(18.85 \times \frac{M_o}{R}\right) = 0$$

Solving the cubic equation:

$L_{e,x} = 7.3403 \text{ ft}$ - Required depth in x-direction,

Considering z-direction:

H_o - Lateral force per length of pile,

$$H_o = \frac{V_z}{D}$$

$$H_o = \frac{(0.172 \text{ kip})}{(36 \text{ in})}$$

$$H_o = 0.057333 \text{ kip/ft}$$

M_o - Moment per length of pile,

$$M_o = \frac{M_x + (V_z H)}{D}$$

$$M_o = \frac{(0.391 \text{ kipft}) + ((0.172 \text{ kip}) \times (0 \text{ ft}))}{(36 \text{ in})}$$

$$M_o = 0.13033 \text{ kipft/ft}$$

Required depth of embedment in earth:

$$L_z^3 - \left(14.14 \times \frac{H_o \times L_z}{R}\right) - \left(18.85 \times \frac{M_o}{R}\right) = 0$$

Solving the cubic equation:

$L_{e,z} = 3.2352 \text{ ft}$ - Required depth in z-direction,

Minimum embedded depth required:

$L_{e,req}$ - Depth of pile required,

$$L_{e,req} = \text{MAX}[L_{e,x}, L_{e,z}]$$

$$L_{e,req} = \text{MAX}[(7.3403 \text{ ft}), (3.2352 \text{ ft})]$$

$$L_{e,req} = 7.34 \text{ ft}$$

L_e - Actual embedded length of pile,

$$L_e = L - h_c - h_2$$

$$L_e = (8.25 \text{ ft}) - (0 \text{ ft}) - (0 \text{ ft})$$

$$L_e = 8.25 \text{ ft}$$

Ratio - Embedded depth

$$\text{Ratio} = \frac{L_{e,req}}{L_e}$$

$$\text{Ratio} = \frac{(7.34 \text{ ft})}{(8.25 \text{ ft})}$$

$$\text{Ratio} = 0.8897$$

Status: **PASS**
Ratio: **0.890**

End-bearing Capacity (ASD)

A - Pile cross-section area

$$A = \pi \left(\frac{D}{2}\right)^2$$

$$A = \pi \times \left(\frac{(36 \text{ in})}{2}\right)^2$$

$$A = 7.0686 \text{ ft}^2$$

q - End-bearing pressure

$$q = \frac{P_c}{A}$$

$$q = \frac{(5.348 \text{ kip})}{(7.0686 \text{ ft}^2)}$$

$$q = 0.75659 \text{ kip/ft}^2$$

Check bearing capacity ratio:

Ratio - Capacity

$$\text{Ratio} = \frac{q}{q_a}$$

$$\text{Ratio} = \frac{(0.75659 \text{ kip/ft}^2)}{(2000 \text{ psf})}$$

$$\text{Ratio} = 0.37829$$

Status: **PASS**
Ratio: **0.380**

Czerniak

Lateral Soil Pressure (ASD):

L/D - Length to least lateral dimension ratio,

$$L/D = \frac{L}{D}$$

$$L/D = \frac{(8.25 \text{ ft})}{(36 \text{ in})}$$

$$L/D = 2.75$$

Since $L/D \leq 10$,

Pile is short.

Considering x-direction:

$H_o = -0.86433 \text{ kip/ft}$ - Lateral force per length of pile,

$M_o = 7.9063 \text{ kipft/ft}$ - Overturning moment per length of pile,

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (7.9063 \text{ kipft/ft}) \times (8.25 \text{ ft})) + (3 \times (-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft})^2)}{(6 \times (7.9063 \text{ kipft/ft})) + (4 \times (-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft}))}$$

$$a = 5.7582 \text{ ft}$$

p - Earth pressure against the pile at distance $a/2$ from resting surface,

$$p = \frac{1.178 [(4 M_o) + (3 H_o L_e)]^2}{L_e^2 [(3 M_o) + (2 H_o L_e)]}$$

$$p = \frac{1.178 \times [(4 \times (7.9063 \text{ kipft/ft})) + (3 \times (-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft}))]^2}{(8.25 \text{ ft})^2 \times [(3 \times (7.9063 \text{ kipft/ft})) + (2 \times (-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft}))]}$$

$$p = 0.19163 \text{ kip/ft}^2$$

s - Earth pressure against the pile at distance L_e ,

$$s = \frac{9.425 [(2 M_o) + (H_o L_e)]}{L_e^2}$$

$$s = \frac{9.425 \times [(2 \times (7.9063 \text{ kipft/ft})) + ((-0.86433 \text{ kip/ft}) \times (8.25 \text{ ft}))]}{(8.25 \text{ ft})^2}$$

$$s = 1.2022 \text{ kip/ft}^2$$

Check lateral soil pressure capacity:

p_a - Allowable lateral soil pressure at depth $a/2$,

$$p_a = R \frac{a}{2}$$

$$p_a = (150 \text{ psf/ft}) \times \frac{(5.7582 \text{ ft})}{2}$$

$$p_a = 0.43186 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity

$$\text{Ratio} = \frac{p}{p_a}$$

$$\text{Ratio} = \frac{(0.19163 \text{ kip/ft}^2)}{(0.43186 \text{ kip/ft}^2)}$$

$$\text{Ratio} = 0.44374$$

Status: **PASS**
Ratio: **0.440**

p_s - Allowable lateral soil pressure at depth L_e ,

$$p_s = R L_e$$

$$p_s = (150 \text{ psf/ft}) \times (8.25 \text{ ft})$$

$$p_s = 1.2375 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity

$$\text{Ratio} = \frac{s}{p_s}$$

$$\text{Ratio} = \frac{(1.2022 \text{ kip/ft}^2)}{(1.2375 \text{ kip/ft}^2)}$$

$$\text{Ratio} = 0.9715$$

Status: **PASS**
Ratio: **0.970**

Considering z-direction:

$H_o = 0.057333 \text{ kip/ft}$ - Lateral force per length of pile,

$M_o = 0.13033 \text{ kipft/ft}$ - Overturning moment per length of pile,

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (0.13033 \text{ kipft/ft}) \times (8.25 \text{ ft})) + (3 \times (0.057333 \text{ kip/ft}) \times (8.25 \text{ ft})^2)}{(6 \times (0.13033 \text{ kipft/ft})) + (4 \times (0.057333 \text{ kip/ft}) \times (8.25 \text{ ft}))}$$

$$a = 5.9864 \text{ ft}$$

p - Earth pressure against the pile at distance $a/2$ from resting surface,

$$p = \frac{1.178 [(4 M_o) + (3 H_o L_e)]^2}{L_e^2 [(3 M_o) + (2 H_o L_e)]}$$

$$p = \frac{1.178 \times [(4 \times (0.13033 \text{ kipft/ft})) + (3 \times (0.057333 \text{ kip/ft}) \times (8.25 \text{ ft}))]^2}{(8.25 \text{ ft})^2 \times [(3 \times (0.13033 \text{ kipft/ft})) + (2 \times (0.057333 \text{ kip/ft}) \times (8.25 \text{ ft}))]}$$

$$p = 0.048737 \text{ kip/ft}^2$$

s - Earth pressure against the pile at distance L_e ,

$$s = \frac{9.425 [(2 M_o) + (H_o L_e)]}{L_e^2}$$

$$s = \frac{9.425 \times [(2 \times (0.13033 \text{ kipft/ft})) + ((0.057333 \text{ kip/ft}) \times (8.25 \text{ ft}))]}{(8.25 \text{ ft})^2}$$

$$s = 0.10159 \text{ kip/ft}^2$$

Check lateral soil pressure capacity:

p_a - Allowable lateral soil pressure at depth $a/2$,

$$p_a = R \frac{a}{2}$$

$$p_a = (150 \text{ psf/ft}) \times \frac{(5.9864 \text{ ft})}{2}$$

$$p_a = 0.44898 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity

$$\text{Ratio} = \frac{p}{p_a}$$

$$\text{Ratio} = \frac{(0.048737 \text{ kip/ft}^2)}{(0.44898 \text{ kip/ft}^2)}$$

$$\text{Ratio} = 0.10855$$

p_s - Allowable lateral soil pressure at depth L_e ,

$$p_s = R L_e$$

$$p_s = (150 \text{ psf/ft}) \times (8.25 \text{ ft})$$

$$p_s = 1.2375 \text{ kip/ft}^2$$

Ratio - Lateral soil capacity


Status: **PASS**
Ratio: **0.110**

$$ratio = \frac{M_o}{p_s}$$

$$Ratio = \frac{(0.10159 \text{ kip/ft}^2)}{(1.2375 \text{ kip/ft}^2)}$$

$$Ratio = 0.082097$$

Status: **PASS**
Ratio: **0.080**



Shear force and Bending moment (x-direction, LRFD)

H_o - Lateral force per length of pile,

$$H_o = \frac{V_z}{D}$$

$$H_o = \frac{(-4.322 \text{ kip})}{(36 \text{ in})}$$

$$H_o = -1.4407 \text{ kip/ft}$$

M_o - Moment per length of pile,

$$M_o = \frac{M_z + (V_z H)}{D}$$

$$M_o = \frac{(39.97 \text{ kipft}) + ((-4.322 \text{ kip}) \times (0 \text{ ft}))}{(36 \text{ in})}$$

$$M_o = 13.323 \text{ kipft/ft}$$

E - Distance from lateral load to resisting surface,

$$E = \frac{M_o}{H_o}$$

$$E = \frac{(13.323 \text{ kipft/ft})}{(-1.4407 \text{ kip/ft})}$$

$$E = 9.248 \text{ ft}$$

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (13.323 \text{ kipft/ft}) \times (8.25 \text{ ft})) + (3 \times (-1.4407 \text{ kip/ft}) \times (8.25 \text{ ft})^2)}{(6 \times (13.323 \text{ kipft/ft})) + (4 \times (-1.4407 \text{ kip/ft}) \times (8.25 \text{ ft}))}$$

$$a = 5.7564 \text{ ft}$$

V_{max} - Max shear force located at depth a ,

$$V_{max} = (H_o D) \left[1 - \left[3 \left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{L_e} \right)^2 + 4 \left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{L_e} \right)^3 \right] \right]$$

$$V_{max} = ((-1.4407 \text{ kip/ft}) \times (36 \text{ in})) \times \left[1 - \left[3 \times \left(\frac{4 \times (9.248 \text{ ft})}{(8.25 \text{ ft})} + 3 \right) \times \left(\frac{(5.7564 \text{ ft})}{(8.25 \text{ ft})} \right)^2 + 4 \times \left(\frac{3 \times (9.248 \text{ ft})}{(8.25 \text{ ft})} + 2 \right) \times \left(\frac{(5.7564 \text{ ft})}{(8.25 \text{ ft})} \right)^3 \right] \right]$$

$$V_{max} = 11.425 \text{ kip}$$

M_{max} - Max bending moment located at depth $a/2$,

$$M_{max} = (H_o D L_e) \left[\left(\frac{E}{L_e} + \frac{a}{2 L_e} \right) - \left[\left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{2 L_e} \right)^3 \right] + \left[\left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{2 L_e} \right)^4 \right] \right]$$

$$M_{max} = ((-1.4407 \text{ kip/ft}) \times (36 \text{ in}) \times (8.25 \text{ ft})) \times \left[\left(\frac{(9.248 \text{ ft})}{(8.25 \text{ ft})} + \frac{(5.7564 \text{ ft})}{2 \times (8.25 \text{ ft})} \right) - \left[\left(\frac{4 \times (9.248 \text{ ft})}{(8.25 \text{ ft})} + 3 \right) \times \left(\frac{(5.7564 \text{ ft})}{2 \times (8.25 \text{ ft})} \right)^3 \right] + \left[\left(\frac{3 \times (9.248 \text{ ft})}{(8.25 \text{ ft})} + 2 \right) \times \left(\frac{(5.7564 \text{ ft})}{2 \times (8.25 \text{ ft})} \right)^4 \right] \right]$$

$$M_{max} = 43.911 \text{ kipft}$$

Shear force and Bending moment (z-direction, LRFD)

H_o - Lateral force per length of pile,

$$H_o = \frac{V_z}{D}$$

$$H_o = \frac{(0.271 \text{ kip})}{(36 \text{ in})}$$

$$H_o = 0.090333 \text{ kip/ft}$$

M_o - Moment per length of pile,

$$M_o = \frac{M_x + (V_z H)}{D}$$

$$M_o = \frac{(0.61 \text{ kipft}) + ((0.271 \text{ kip}) \times (0 \text{ ft}))}{(36 \text{ in})}$$

$$M_o = 0.20333 \text{ kipft/ft}$$

E - Distance from lateral load to resisting surface,

$$E = \frac{M_o}{H_o}$$

$$E = \frac{(0.20333 \text{ kipft/ft})}{(0.090333 \text{ kip/ft})}$$

$$E = 2.2509 \text{ ft}$$

a - Distance from resting surface to pivot point,

$$a = \frac{(4 M_o L_e) + (3 H_o L_e^2)}{(6 M_o) + (4 H_o L_e)}$$

$$a = \frac{(4 \times (0.20333 \text{ kipft/ft}) \times (8.25 \text{ ft})) + (3 \times (0.090333 \text{ kip/ft}) \times (8.25 \text{ ft})^2)}{(6 \times (0.20333 \text{ kipft/ft})) + (4 \times (0.090333 \text{ kip/ft}) \times (8.25 \text{ ft}))}$$

$$a = 5.9878 \text{ ft}$$

V_{max} - Max shear force located at depth a ,

$$V_{max} = (H_o b) \left[1 - \left[3 \left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{L_e} \right)^2 \right] + \left[4 \left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{L_e} \right)^3 \right] \right]$$

$$V_{max} = ((0.090333 \text{ kip/ft}) \times (36 \text{ in})) \times \left[1 - \left[3 \times \left(\frac{4 \times (2.2509 \text{ ft})}{(8.25 \text{ ft})} + 3 \right) \times \left(\frac{(5.9878 \text{ ft})}{(8.25 \text{ ft})} \right)^2 \right] + \left[4 \times \left(\frac{3 \times (2.2509 \text{ ft})}{(8.25 \text{ ft})} + 2 \right) \times \left(\frac{(5.9878 \text{ ft})}{(8.25 \text{ ft})} \right)^3 \right] \right]$$

$$V_{max} = 0.31308 \text{ kip}$$

M_{max} - Max bending moment located at depth $a/2$,

$$M_{max} = (H_o b L_e) \left[\left(\frac{E}{L_e} + \frac{a}{2 L_e} \right) - \left[\left(\frac{4E}{L_e} + 3 \right) \left(\frac{a}{2 L_e} \right)^3 \right] + \left[\left(\frac{3E}{L_e} + 2 \right) \left(\frac{a}{2 L_e} \right)^4 \right] \right]$$

$$M_{max} = ((0.090333 \text{ kip/ft}) \times (36 \text{ in}) \times (8.25 \text{ ft})) \times \left[\left(\frac{(2.2509 \text{ ft})}{(8.25 \text{ ft})} + \frac{(5.9878 \text{ ft})}{2 \times (8.25 \text{ ft})} \right) - \left[\left(\frac{4 \times (2.2509 \text{ ft})}{(8.25 \text{ ft})} + 3 \right) \times \left(\frac{(5.9878 \text{ ft})}{2 \times (8.25 \text{ ft})} \right)^3 \right] + \left[\left(\frac{3 \times (2.2509 \text{ ft})}{(8.25 \text{ ft})} + 2 \right) \times \left(\frac{(5.9878 \text{ ft})}{2 \times (8.25 \text{ ft})} \right)^4 \right] \right]$$

$$M_{max} = 1.0935 \text{ kipft}$$

Minimum Reinforcement Check (LRFD)

Parameters:

$f'_{ck} = 2.5 \text{ ksi}$ - Concrete strength,
 $f_{yk} = 60 \text{ ksi}$ - Longitudinal reinforcement strength,
 $\phi = 0.65$ - Reduction factor for axial strength,
 $\alpha = 0.85$ - Alpha factor for axial strength,
 $A_g = 1017.9 \text{ in}^2$ - Gross area of concrete,

Table 22.4.2.1

Longitudinal reinforcement:

Required reinforcement due to axial load, $A_{st,required}$

22.4.2.2, 10.6.1.1

$A_{st,required}$

$$A_{st,required} = \text{Min} \left[\frac{\frac{P}{\phi \alpha} - (0.85 f'_{ck} A_g)}{f_{yk} - (0.85 f'_{ck})}, (0.08 A_g) \right]$$

$$A_{st,required} = \text{Min} \left[\frac{\frac{(8.049 \text{ kip})}{(0.65) \times (0.85)} - (0.85 \times (2.5 \text{ ksi}) \times (1017.9 \text{ in}^2))}{(60 \text{ ksi}) - (0.85 \times (2.5 \text{ ksi}))}, (0.08 \times (1017.9 \text{ in}^2)) \right]$$

$$A_{st,required} = -37.122 \text{ in}^2$$

A_{min} - Governing minimum reinforcement area,

$$A_{min} = \text{Max} [A_{st,required}, (0.0018 A_g)]$$

$$A_{min} = \text{Max} [(-37.122 \text{ in}^2), (0.0018 \times (1017.9 \text{ in}^2))]$$

$$A_{min} = 1.8322 \text{ in}^2$$

n_{rebar} - Required number of reinforcement,

$$n_{rebar} = \frac{A_{min}}{A_{rebar}}$$

$$n_{rebar} = \frac{(1.8322 \text{ in}^2)}{(0.3068 \text{ in}^2)}$$

$$n_{rebar} = 6$$

A_{st} - Actual total reinforcement area,

$$A_{st} = n_{rebar} \frac{\pi d_{bar}^2}{4}$$

$$A_{st} = (6) \times \frac{\pi \times (0.625 \text{ in})^2}{4}$$

$$A_{st} = 1.8408 \text{ in}^2$$

Ratio - Capacity

$$\text{Ratio} = \frac{A_{min}}{A_{st}}$$

$$\text{Ratio} = \frac{(1.8322 \text{ in}^2)}{(1.8408 \text{ in}^2)}$$

$$\text{Ratio} = 0.99533$$

25.2.3

s_{rebar} - Minimum spacing of reinforcement,

$$s_{rebar} = \text{Max} [1.5, (1.5 d_{bar})]$$

$$s_{rebar} = \text{Max} [1.5, (1.5 \times (0.625 \text{ in}))]$$

$$s_{rebar} = 1.5 \text{ in}$$

Ties:

25.7.2.2

Since longitudinal reinforcement is \leq No. 10 \varnothing : Use #3(0.375 in)

25.7.2.1

s_{ties} - Maximum center-to-center spacing of ties,

$$s_{ties} = \text{Min} [(16 d_{bar}), (48 d_{ties}), D]$$

$$s_{ties} = \text{Min} [(16 \times (0.625 \text{ in})), (48 \times (0.375 \text{ in})), (36 \text{ in})]$$

$$s_{ties} = 10 \text{ in}$$

Summary:

Status: **PASS**
Ratio: **1.000**

Main reinforcement: **6 - #5 (0.625 in)**
Ties: **#3(0.375 in) - 10 in**

Axial Compression Strength (ACI 318-19, LFRD)

22.4.2.2

ϕP_N - Allowable axial compressive strength

$$\phi P_N = \phi 0.85 [(0.85 f'_{ck} [A_g - A_{st}]) + (f_{yk} A_{st})]$$

$$\phi P_N = (0.65) \times 0.85 \times [(0.85 \times (2.5 \text{ ksi}) \times [(1017.9 \text{ in}^2) - (1.8408 \text{ in}^2)]) + ((60 \text{ ksi}) \times (1.8408 \text{ in}^2))]$$

$$\phi P_N = 1253.9 \text{ kip}$$

Ratio - Capacity

$$\text{Ratio} = \frac{P}{\phi P_N}$$

$$\text{Ratio} = \frac{(8.049 \text{ kip})}{(1253.9 \text{ kip})}$$

$$\text{Ratio} = 0.0064191$$

Status: **PASS**
Ratio: **0.010**

Shear Strength (ACI 318-19, LFRD)

Parameters:

22.5.2.2

$b_w = 36 \text{ in}$ - Effective width,
 d - Effective depth

$$d = 0.80 D$$

$$d = 0.80 \times (36 \text{ in})$$

$$d = 28.8 \text{ in}$$

22.5.5.1.3

λ_s - size effect modification factor

$$\lambda_s = \text{MIN} \left[\sqrt{\frac{2}{1 + \frac{d}{10}}}, 1 \right]$$

$$\lambda_s = \text{MIN} \left[\sqrt{\frac{2}{1 + \frac{(28.8 \text{ in})}{10}}}, 1 \right]$$

$$\lambda_s = 0.71796$$

22.5.5.1.1

The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$.
 $V_{c,max}$ - Max shear strength of concrete

$$V_{c,max} = 5 \lambda_s \sqrt{f'_{ck}} b_w d$$

$$V_{c,max} = 5 \times (0.71796) \times \sqrt{(2500 \text{ psi})} \times (36 \text{ in}) \times (28.8 \text{ in})$$

$$V_{c,max} = 186.09 \text{ kip}$$

22.5.5.1.1(a)

The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$, $P = 8.049 \text{ kip} \rightarrow 8049 \text{ lbf}$.
 $V_{c,a}$ - Shear strength of concrete (a)

$$V_{c,a} = \left[2 \lambda_s \sqrt{f'_{ck}} + \frac{P}{6 A_g} \right] b_w d$$

$$V_{c,a} = \left[2 \times (0.71796) \times \sqrt{(2500 \text{ psi})} + \frac{(8049 \text{ lbf})}{6 \times (1017.9 \text{ in}^2)} \right] \times (36 \text{ in}) \times (28.8 \text{ in})$$

$$V_{c,a} = 75.804 \text{ kip}$$

22.5.5.1.2

The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$.
 $V_{c,b}$ - Shear strength of concrete (b)

$$V_{c,b} = \left[2 \lambda_s \sqrt{f'_{ck}} + (0.05 f'_{ck}) \right] b_w d$$

$$V_{c,b} = \left[2 \times (0.71796) \times \sqrt{(2500 \text{ psi})} + (0.05 \times (2500 \text{ psi})) \right] \times (36 \text{ in}) \times (28.8 \text{ in})$$

$$V_{c,b} = 204.04 \text{ kip}$$

V_c - Governing shear strength of concrete

$$V_c = \text{Min}[V_{c,max}, V_{c,a}, V_{c,b}]$$

$$V_c = \text{Min}[(186.09 \text{ kip}), (75.804 \text{ kip}), (204.04 \text{ kip})]$$

<p>22.5.1.2</p> <p>22.5.8.5.3</p> <p>22.5.1.1</p>	<p style="text-align: center;">$V_c = 75.804 \text{ kip}$</p> <p>The following variables were converted to be consistent with empirical formula $f'_{ck} = 2.5 \text{ ksi} \rightarrow 2500 \text{ psi}$.</p> <p>$V_{s,a}$ - Shear strength of steel (a)</p> $V_{s,a} = 8 \sqrt{f'_{ck}} b_w d$ $V_{s,a} = 8 \times \sqrt{(2500 \text{ psi})} \times (36 \text{ in}) \times (28.8 \text{ in})$ $V_{s,a} = 414.72 \text{ kip}$ <p>A_v - Ties rebar area,</p> $A_v = \frac{\pi d_{ties}^2}{4}$ $A_v = \frac{\pi \times (0.375 \text{ in})^2}{4}$ $A_v = 0.11045 \text{ in}^2$ <p>$V_{s,b}$ - Shear strength of steel (b)</p> $V_{s,b} = \frac{2 A_v f_{yw} d}{s_{ties}}$ $V_{s,b} = \frac{2 \times (0.11045 \text{ in}^2) \times (60 \text{ ksi}) \times (28.8 \text{ in})}{(10 \text{ in})}$ $V_{s,b} = 38.17 \text{ kip}$ <p>V_s - Governing shear strength of steel</p> $V_s = MIN[V_{s,a}, V_{s,b}]$ $V_s = MIN[(414.72 \text{ kip}), (38.17 \text{ kip})]$ $V_s = 38.17 \text{ kip}$ <p>ϕV_n - Allowable shear strength</p> $\phi V_n = \phi (V_c + V_s)$ $\phi V_n = (0.65) \times ((75.804 \text{ kip}) + (38.17 \text{ kip}))$ $\phi V_n = 74.084 \text{ kip}$ <p>Considering x-direction:</p> <p>$V_{max} = 11.425 \text{ kip}$ - Maximum shear force in the x-direction, Ratio - Capacity</p> $Ratio = \frac{V_{max}}{\phi V_n}$ $Ratio = \frac{(11.425 \text{ kip})}{(74.084 \text{ kip})}$ $Ratio = 0.15422$ <p>Considering z-direction:</p> <p>$V_{max} = 0.31308 \text{ kip}$ - Maximum shear force in the z-direction, Ratio - Capacity</p> $Ratio = \frac{V_{max}}{\phi V_n}$ $Ratio = \frac{(0.31308 \text{ kip})}{(74.084 \text{ kip})}$ $Ratio = 0.004226$	<p>Status: PASS Ratio: 0.150</p> <p>Status: PASS Ratio: 0.000</p>
	<p>Flexural Strength (ACI 318-19, LRFD)</p> <p>S_m - Section modulus</p> $S_m = \frac{\pi D^3}{32}$ $S_m = \frac{\pi \times (36 \text{ in})^3}{32}$	

<p>14.5.2.1b</p>	<p style="text-align: center;">$S_m = 4580.4 \text{ in}^3$</p> <p>$\lambda = 1$ - Concrete modification factor (Normal concrete), Allowable flexural strength: M_n shall be the lesser of: $\phi M_{n,1}$</p> $\phi M_{n,1} = \phi \times 5 \times \lambda \times \sqrt{f'_c} \times S_m$ $\phi M_{n,1} = 0.65 \times 5 \times 1 \times \sqrt{2.5 \text{ ksi}} \times 4580.442 \text{ in}^3$ $\phi M_{n,1} = 62.027 \text{ kipft}$ <p>$\phi M_{n,2}$</p> $\phi M_{n,2} = \phi \times 0.85 \times f'_c \times S_m$ $\phi M_{n,2} = (0.65) \times 0.85 \times (2.5 \text{ ksi}) \times (4580.4 \text{ in}^3)$ $\phi M_{n,2} = 527.23 \text{ kipft}$ <p>Therefore, ϕM_n - Allowable flexural strength,</p> $\phi M_n = \text{MIN}[\phi M_{n,1}, \phi M_{n,2}]$ $\phi M_n = \text{MIN}[(62.027 \text{ kipft}), (527.23 \text{ kipft})]$ $\phi M_n = 62.027 \text{ kipft}$ <p>Considering x-direction: $M_{max} = 43.911 \text{ kipft}$ - Maximum moment in the x-direction, Ratio - Capacity</p> $\text{Ratio} = \frac{M_{max}}{\phi M_n}$ $\text{Ratio} = \frac{(43.911 \text{ kipft})}{(62.027 \text{ kipft})}$ $\text{Ratio} = 0.70794$	<p>Status: PASS Ratio: 0.710</p>
	<p>Considering z-direction: $M_{max} = 1.0935 \text{ kipft}$ - Maximum moment in the z-direction, Ratio - Capacity</p> $\text{Ratio} = \frac{M_{max}}{\phi M_n}$ $\text{Ratio} = \frac{(1.0935 \text{ kipft})}{(62.027 \text{ kipft})}$ $\text{Ratio} = 0.017629$	<p>Status: PASS Ratio: 0.020</p>